

SECTION 5
REVIEW OF EXISTING SANITARY SEWER DATA

5.01 PREVIOUS STUDIES AND REPORTS

A. Review of Existing Information

The City has completed two “formal” collection system analyses over the last decade. In 1999, a *Sanitary Sewer Relief Plan* provided an analysis of selected storm and sanitary sewers in the City. This evaluation provides a summary of information relative to the sanitary sewers in the study area; pipe diameters, slopes, tributary areas, and estimated flow rates are presented in a tabular format. The report also presents some preliminary recommendations for potential short-term operational changes that could be implemented as well as potential long-term infrastructure modifications that could be installed to address localized flooding issues.

In 2007, a *Sanitary Sewer Flow Monitoring and Analysis* was completed. This study included flow monitoring within the collection system, analysis of the flow metering data, development of a hydraulic model, analysis of the existing collection system under wet weather conditions, and recommendations for potential infrastructure improvements.

In addition to these two evaluations, City personnel have collected flow metering and rain gauge data and completed manhole inspections, smoke testing, and sanitary sewer televising. A discussion of this information can be found in Section 5.02.

1. Sanitary Sewer Relief Plan (1999)

This study was completed to develop an emergency operation plan for the KWU for four trunk sewers that have experienced flooding within the City. Approximately 11,000 feet of interceptor sewers ranging in size from 6 to 18 inches were analyzed. Trunk Sewer No. 1 discharges into an 18-inch interceptor at the intersection of 54th Avenue and 60th Street (Trunk Sewer No. 1 combines with flows from the study area at the intersection of Pershing Boulevard and 60th Street). Trunk Sewer Nos. 2, 3, and 4 are located within the Forest Park study area and discharge into an 18-inch interceptor sewer at the intersection of 60th Street and Pershing Boulevard. The following summary was taken from the *Sanitary Sewer Relief Plan* and includes the description, capacity analysis results, and recommendations for Trunk Sewer Nos. 2, 3, and 4. A copy of pertinent report figures can be found in Appendix B. These figures show the locations of the various trunk sewers analyzed as part of the 1999 evaluation.

a. Trunk Sewer No. 2

Trunk Sewer No. 2 consists of 8- and 10-inch sewers and is located in 61st Street and Pershing Boulevard and flows from 54th Street to the connection with the 18-inch interceptor sewer at the intersection of 60th Street and Pershing Boulevard. No backups were reported along this trunk sewer during a storm on April 23, 1999, and four backups were reported after a storm on June 15, 1999. Ponding was observed over manholes 669 (61st Street and 51st Avenue) and 884 (61st Street and 48th Avenue). A capacity analysis of the sewer was completed and indicated surcharging when a simulated wet weather flow of 450 gpm was added to the design flow.

The report recommended the use of a 600 gpm portable bypass pump at manhole 884 (intersection of 61st Street and 48th Avenue) during intense rain events to relieve the sewer. The report also suggested (after system inspection, I/I removal, and flow monitoring) two potential permanent alternatives of relaying 2,600 feet of 8- to 10-inch sewer with 12-inch sewer from manhole 6090 to 669 or constructing a 500 gpm “peak flow” pumping station at manhole 885 with 725 feet of 6-inch force main discharging to the 18-inch interceptor sewer in 60th Street.

The report also included a cursory review of the storm sewer along 61st Street west of 49th Avenue, which indicated frequent surcharging during both 2- and 10-year storm events.

b. Trunk Sewer No. 3

Trunk Sewer No. 3 is an 8-inch-diameter sewer that flows north along 51st Avenue from 63rd Street to 61st Street where it discharges into Truck Sewer No. 2. Three basement backups were reported in this trunk sewer after the April 23, 1999, storm and six backups were reported after the June 15, 1999 storm (two of these homes reported backups from both storms).

The report indicates the surcharging along this sewer is likely related to the surcharging in Trunk Sewer No. 2.

The report also indicated a cursory review of the nearby storm sewer in 51st Avenue suggests the storm sewer is undersized for both 2- and 10-year storm events.

c. Trunk Sewer No. 4

Trunk Sewer No. 4 is an 8-inch-diameter sewer that flows north along 50th Avenue from 63 Street to 61st Street where it discharges into Trunk Sewer No. 2. Two basement backups were reported in this trunk sewer after the April 23, 1999, storm and one backup was reported after the June 15, 1999 storm.

The report indicates the surcharging along this sewer is likely related to the surcharging in Trunk Sewer No. 2.

The report also indicated a cursory review of the nearby storm sewer in 50th Avenue suggests the storm sewer is undersized for both 2- and 10-year storm events.

d. Recommendations

Following are the recommendations from the report:

- (1) Conduct sewer manhole inspections and smoke testing of sewers in the service areas tributary to trunk sewers.

- (2) Review and correct landscaping and drainage around residential structures susceptible to flooding.
- (3) Initiate operation of new portable bypass pumps.
- (4) Install flow monitors and manhole surcharge slide monitors in areas of suspected surcharging.
- (5) Subscribe to weather forecasting service to predict likelihood of surcharging.
- (6) Install Supervisory Control and Data Acquisition (SCADA) telemetry and a continuous surcharge monitoring station at manhole 2.09.

If backups and/or chronic bypassing persists after the completion of the above recommendations, the following long-term measures were recommended.

- (1) Relay Trunk Sewer No. 2 as described above.
- (2) Conduct public education program.
- (3) Investigate undersized storm sewers.

2. Sanitary Sewer Flow Monitoring and Analysis for the Kenosha Water Utility (2007)

This study was completed to identify causes of high flows and actions necessary to relieve surcharging in the study areas. Fifteen flow meters were installed in various manholes; three of the meters were installed in the Forest Park Study Area. The following summary includes only information for the current Forest Park Study area (identified as Basin 1 in the 2007 report.) A copy of the pertinent report figures can be found in Appendix B.

a. Flow Metering

Flow meters were operable at most sites by March 9, 2005. The flow meters were removed on October 7, 2005. Because of dry weather, the flow meters were reinstalled at the same sites on March 9, 2006, and were removed October 31, 2006. Collected flow data was analyzed to determine base flow, instantaneous peak flow, 24-hour peak flow, and independent I/I. Wet weather inflow was projected for the 5-, 10-, 25-, and 50-year design storm events. The 3-hour 5-year storm and 3-hour 10-year storm were used for calibration and verification of the hydraulic model.

b. Basin Results

Basin 1 had three flow meters, B-5, B-6, and B-7, that were tributary to the Forest Park Study Area. The 24-hour peaking factors for B-5 (in 60th Street east of Pershing Boulevard), B-6 (in Pershing Blvd just south of 60th Street), and B-7 (just west of the intersection at 61st Street and 49th Avenue) were determined to be 3.7, 7.6, and 9.4,

respectively. Instantaneous peaking factors were 7.2, 19.5, and 33.6, respectively. The high peaking factors for B-6 and B-7 indicated the potential for large volumes of I/I.

c. XPSWMM Modeling

An XPSWMM model was created for the study area. The model consisted of dry weather and wet weather inputs.

Dry weather inputs were derived by averaging three consecutive daily flows following a period of five days with little or no rain. Dry weather inputs were assigned to various manholes (sewersheds) in the study area, and model parameters (average per-capita or per-acre daily wastewater flow rates) were adjusted to match the model-simulated output to the measured flow.

Wet weather inputs were generated using projected design storm peak flow rates, based on monitored precipitation data. The time of concentrations, curve number, and basin areas were adjusted to calibrate the model for the 3-hour, 5-year projected design storm, and the 3-hour, 10-year projected design storm was used to verify the model. The calibrated model was then used to project the 3-hour, 50-year event used to develop the conveyance/storage alternatives.

d. Recommendations

(1) Infiltration/Inflow Removal

The report recommended reducing I/I in the sanitary sewer system. The report proposed sealing the manhole frame and chimney interface and installing solid gasketed manhole covers as two very cost-effective approaches. The report also recommended removing illegally connected sump pumps and downspouts.

(2) Conveyance/Storage Alternatives

The report provided recommendations for conveyance and storage alternatives. One conveyance recommendation was to replace the 10-inch sewers in 61st Street and Pershing Boulevard and 18-inch interceptor in 60th Street with 24-inch sewers. The proposed storage option to relieve the 61st Street trunk sewer was a 2.4-million-gallon storage facility between 49th and 46th Avenues.

5.02 CITY OF KENOSHA EXISTING INFORMATION

The City has collected flow metering data and rain gauge data and completed manhole inspections, smoke testing, and sanitary sewer televising.

A. Flow Metering Data

Flow metering data was collected in 2008 at MH-5724 (also called location B-7, 4907 61st Street) and in 2009 at MH-5724 and MH-999 (for September and October, 65th Street and 48th Avenue). MH-5724 receives flow from the western half of the north basin and MH-999 from the entire south basin.

B. Rain Gauge Data

The City has provided rain gauge data for the June 19, 2009, storm event from the wastewater treatment plant and Kenosha Water Utility (KWU). The wastewater treatment plant and KWU received approximately 4.06 inches and 3.45 inches of rain, respectively.

C. Manhole Inspections

Manhole inspection reports were provided for the entire Forest Park Study Area. Section 3 presented an overview of the manhole inspection results.

D. Smoke Testing

Smoke testing results were provided for the entire Forest Park Study Area. Section 3 presented an overview of the smoke testing results.

E. Sanitary Sewer Televising

Sanitary sewer televising results were provided for many sewers in the study area. Section 3 presented an overview of the sewers televised and the results of the televising.

SECTION 6
ENGINEERING ANALYSIS: SANITARY SEWER

6.01 HYDRAULIC ANALYSIS

A. Purpose of Evaluation

A sanitary sewer system model was developed for two basins (referred to as the north and south basins) in the Forest Park study area. Figure 6.01-1 shows the study area limits, the existing sanitary sewers in the area, and the location of previously installed flow meters. Figure 6.01-2 shows the sewers included in the hydraulic model. The hydraulic model was used to estimate flow rates and depths in the sanitary sewer system based on flow metering data and sewer system characteristics. The model evaluation was used to develop an overall understanding of the operation of the existing collection system under a variety of wet weather conditions. The results of this evaluation are discussed in this section. The model was also used to evaluate conveyance alternatives for the study area. The alternatives analysis is presented in Section 8.

B. Methodology

For the sanitary sewer evaluation, the computer software XPSWMM was utilized. This software allows the user to evaluate the operation of a collection system under surcharged and nonsurcharged conditions.

Dry and wet weather input hydrographs based on historical flow metering data were developed for this evaluation. 2008 and 2009 flow metering data was available from the City at the flow meter location B-7, located in the north basin. Flow metering results for three locations in the north basin (B-5, B-6, and B-7) from 2005 and 2006 were also available. Figure 6.01-1 shows the location of the flow meters.

Flow metering data was available for MH-999 (referred to as S-1) for September and October 2009. This metering location is in the south basin of the Forest Park study area. Figure 6.01-1 shows the location of this flow meter.


Table 6.01-1 summarizes the theoretical rainfall intensities associated with the various rainfall events included in the analysis. Rainfall intensities were used in conjunction with flow metering data to develop wet weather model input hydrographs for various design storms. This is discussed in more detail later in this section.

The hydraulic model was used to calculate the hydraulic capacity of the existing sanitary sewer system under existing conditions. Figure 6.01-2 shows the sewers included in the hydraulic model, along with the flow metering locations. Figure 6.01-3 shows a schematic of the sanitary sewer network as modeled, including pertinent pipe and manhole information. Input to the hydraulic model includes the following:

Recurrence Interval	Theoretical Rainfall Intensity ¹ (in/hr)
6-month	1.42
1-year	1.74
2-year	2.14
5-year	2.58
10-year	2.90
25-year	3.36
50-year	3.70
100-year	4.04

¹ SEWRPC Technical Memo No. 40—Rainfall Frequency in the Southeastern Wisconsin Region.

Table 6.01-1 Theoretical Rainfall Intensities



Legend

- Meter # - Meter Manhole
- Node # - Model Output Node
- North Basin Modeled Sewers
- South Basin Modeled Sewers
- Sanitary Manhole
- Sanitary Sewer
- North Basin
- South Basin

MODELED SEWERS
FOREST PARK AREA STORM AND SANITARY MANAGEMENT PLAN
CITY OF KENOSHA
KENOSHA COUNTY, WISCONSIN



FIGURE 6.01-2
1540.001

- The physical geometry of the sanitary sewer system, including pipe sizes and shapes, and ground and invert elevations. For this project, physical information regarding the sanitary system was obtained from the City's sanitary sewer GIS layer along with record drawing information provided by the City.
- Roughness coefficients for existing sewers (referred to as conduits in the model).
- Input hydrographs at critical manholes (referred to as nodes in the model) in the system. For this project, hydrographs were computed using existing flow metering data.
- Boundary conditions defining starting water surface elevations and outlet conditions. For the north basin, the downstream boundary condition was an assumed water surface elevation in the sewers located in 60th Street. For the south basin, the downstream boundary condition was assumed water surface elevations in manholes 603 and 3208 (Refer to Figure 6.02-2).
- Appendix C contains tabular data associated with the sanitary sewer hydraulic model.

Output information from the Extended Transport (EXTRAN) model includes the following:

- Time histories of flows and depths through individual sanitary sewer pipes for various modeled dry and wet weather events.
- Estimates of wastewater volumes in the system at various locations for wet weather events. This can be used to size potential wet weather storage facilities.

1. Dry Weather Model Input

Dry weather average daily base flow at metering locations B-7 and S-1 was determined by averaging all flow data from days where there was no measured rainfall and the metered flows did not exhibit elevated base flows due to previously documented wet weather. Based on this methodology, the dry weather average daily base flows for B-7 and S-1 were determined to be 21 gpm and 34 gpm, respectively.

Dry weather peak base flow for areas between metering locations B-7 and B-6 was determined to be approximately 2.5 times the average daily base flow observed in B-7 based on historical flow metering information. This is based on a comparison of B-6 and B-7 during the 2005 to 2006 metering session. A dry weather peak base flow of $21 \text{ gpm} \times 2.5 = 52.5 \text{ gpm}$ was used.

Dry weather peak base flow for tributary areas upstream of metering location B-5 and Pershing Boulevard was assumed to be 709 gpm based on historical flow metering results. Although the majority of the sewers located in the B-5 basin were not included in the computer model, it was necessary to determine the flows in the 60th Street sewers, since the north basin of the study area discharges to the 60th Street sewers and, therefore, impacts the model and the operation of the sewers in the study area. Refer to Figures 6.01-1 through 6.01-3 for a delineation of the modeled sewers and the sewers tributary to the Pershing Boulevard/60th Street intersection.

The hydraulic model requires that the dry weather daily diurnal variation in flow be entered. The diurnal flow variation documents the routine changes in wastewater flow rate that occur

throughout a typical day. Peak dry weather flows typically occur in the morning (7 to 9 A.M. ±) with another smaller peak in the evening as residents return home. Historical flow metering was used to document the daily diurnal flow variation at metering locations B-7 and S-1. The diurnal pattern of flow variation for Meter B-7 was then used to develop dry weather flow input diurnal variations in the north basin, while the diurnal variation at Meter S-1 was used to develop dry weather inputs in the south basin.

Dry weather flows were entered at selected nodes (manholes) for each basin. For the north basin a percentage flow for each node was calculated by summing the number of homes tributary to the selected node. For example, 12 homes are tributary to MH-3090 (located in the north basin) out of 146 homes tributary to flow meter B-7. Thus, the dry weather flow for MH-3090 is:

$$[(12 \text{ homes}/146 \text{ homes}) * (21 \text{ gpm}) = 1.7 \text{ gpm}]$$

For the south basin a percentage flow for each node was calculated for two tributaries. The tributary area upstream of MH-2920 includes recently constructed subdivisions where more typical amounts of I/I are expected. The tributary area downstream of MH-2920 includes older homes where higher amounts of I/I would be expected. Refer to the following wet weather model input section for additional detail on calculating the percentage flow for each node in the south basin.

Figure 6.01-3 shows the location of dry weather flow input manholes.

2. Wet Weather Model Input

Wet weather inputs for Basin B-7 were obtained from 15-minute flow metering data provided by the City. The June 19, 2009, rainfall event was utilized as the base modeled storm event (Appendix D contains an analysis of the rainfall and flow metering information associated with the June 19, 2009 event). The flow metering data was used to obtain hydrographs for the rainfall event. Wet weather flows were distributed to the same nodes that received dry weather inputs and the same flow distribution methodology was used as previously described for the north basin. For example, 12 homes are tributary to MH-3090 out of 146 homes tributary to Basin B-7. Thus, the 15-minute flow metering data for MH-3090 is:

$$[(12 \text{ homes}/146 \text{ homes}) * (15 \text{ minute measured flow [cfs])}] = \text{MH-3090 Wet Weather Input (cfs)}.$$

Flow metering data obtained from the June 19, 2009, storm event was used directly as wet weather input for nodes upstream of Meter B-7.

For the south basin, the peak flow from the area tributary to MH-2920 was determined using conventional design parameters since this area consists of newer homes with more typical I/I expected. The peak flow is shown below: A peaking factor of 4 was assumed.

$$\text{Peak Flow} = 100 \text{ gpcd} * 2.54 \text{ people/home} * 4 * 67 \text{ homes} = 68,072 \text{ gal/day}.$$

This peak flow rate was divided by the estimated 100-year flow rate at metering point S-1 to determine the percentage of flow to MH-2920.

68,072 gal/day/3,100,000 gal/day = 0.022 (2.2%) (Percentage of S-1 Flow tributary to MH-2920)

Using the percentage above, wet weather and dry weather flows were distributed to each input node by summing the number of homes tributary to the selected node. For example, 8 homes are tributary to MH-2921 out of 67 homes tributary to the MH-2920 basin. Therefore, the wet weather flow to MH-2921 is:

$$(8 \text{ homes}/67 \text{ homes}) \times 0.022 \times 68,072 \text{ gpd} = 179 \text{ gpd}$$

Flow metering data was not available for the June 19, 2009, storm event for Basins B-6 and B-5 (The metering data available for these basins was during 2005 and 2006). However, existing flow metering data from the 2005/2006 flow metering period was used to compare the responses of the basins during a wet weather event.

Table 6.01-2 shows two methods that were used to determine theoretical peak flows for Basin B-6. Previous evaluations of the study area utilized a rainfall event that occurred on March 13, 2006. This was the rainfall event that resulted in the largest rainfall-induced peak flow during the 2005 to 2006 metering period. A comparison of the instantaneous peak flow metered for Basin B-6 and Basin B-7 in March 2006 indicates a peak flow ratio of 0.86.

An alternative method for comparing theoretical peak flows from tributary areas is to compare the total number of homes tributary to each flow meter. Table 6.01-2 compares the number of homes tributary to each basin. The tributary home ratio of Basin B-6 to Basin B-7 is 0.96.

These two comparisons, a peak flow ratio and a tributary home ratio, indicate the anticipated peak flows from Basin B-6 would be expected to be slightly less than the flows from Basin B-7. Given the uncertainty associated with flow metering, I/I sources, and other factors, it was conservatively assumed the flow for Basin B-6 would be equal to the flow from Basin B-7.

Meter Location/ Basin ID	Instantaneous Peak Flow ¹ (gpm)	Tributary Homes
B-6	649	140
B-7	754	146
Ratio–B-6/B-7	0.86	0.96

¹ For March 13, 2006, rainfall event.

**Table 6.01-2 Basin Comparison–
Basins B-6 and B-7**

Meter Location / Basin ID	Instantaneous Peak Flow ¹ (gpm)	Tributary Homes
B-5	5,094	964
B-7	754	146
Ratio–B-5/B-7	6.76	6.60

¹ For March 13, 2006, rainfall event.

**Table 6.01-3 Basin Comparison–
Basins B-5 and B-7**

A similar procedure was used to develop an estimated peak flow from Basin B-5. Table 6.01-3 show the two methods used in the Basin B-5 analysis. Based on the peak flow and tributary home comparison, Basin B-5 peak flows were assumed to be 7.0 times the peak flows from Basin B-7.

For Basin S-1, flow metering data was not available for the June 19, 2009, storm event, nor was there data available for 2005/2006. Data was available for September/October 2009.

Table 6.01-4 presents a comparison of wet weather daily average flow and instantaneous peak flow for Basins S-1 and B-7. It is recommended that additional flow metering data be obtained for Basin S-1 to confirm the assumptions used in the modeling.

Meter Location/ Basin ID	Dry Weather Base Flow (gpm)	Wet Weather Daily Average Flow ¹ (gpm)	Instantaneous Peak Flow (gpm)	Tributary Homes
S-1	34	320	560	267
B-7	21	202	360	146
Ratio–S-1/B-7	1.62	1.58	1.56	1.83

¹ For October 23, 2009 rainfall event.

Table 6.01-4 Basin Comparison–Basins S-1 and B-7

To further evaluate and compare the two basins, the ratio of wet weather average to dry weather base flow and the ratio of instantaneous peak flow to dry weather base flow were compared for the October rainfall event. Table 6.01-5 summarizes this comparison.

Meter Location/ Basin ID	Dry Weather Base Flow (gpm)	Wet Weather Daily Average Flow ¹ (gpm)	Ratio–Wet Weather Average to Dry Weather Base	Instantaneous Peak Flow (gpm)	Ratio–Instantaneous Peak to Dry Weather Base
S-1	34	320	9.4	560	16.5
B-7	21	202	9.6	360	17.1

¹ For October 23, 2009 rainfall event.

Table 6.01-5 Basin Comparison–Basins S-1 and B-7

The comparisons presented in Table 6.01-5 indicate the two basins responded in a similar fashion to the October 2009 rainfall event. Therefore, metered peak flows for Basin B-7 were multiplied by two to approximate the peak flows in Basin S-1. Given the ratios established in Table 6.01-4 (1.56 to 1.8), this should represent a slightly conservative approach to approximating these flows.

It should be noted that development of the peak flow approximations was required because flow metering information was not available for all metering sites for the June 19, 2009, rainfall event. This necessitated the development of ratios comparing B-7 and other previously metered basins. KWU staff continue to maintain flow meters in the study area and continue to gather wet weather data that adds to the understanding of the operation of the sanitary sewers during wet weather. Prior to design of any collection system improvements, all available flow metering information should be reevaluated, and a final design flow should be established for all improvements. This may require additional flow metering data. It is worth noting that KWU staff continue to identify and remove sources of I/I in the sanitary sewer system, thereby potentially reducing the peak wet weather flow in the system. Since historical flow metering results do not

reflect these reductions in I/I and peak flow rates, more current flow metering data would be particularly valuable.

3. Design Storm Development

Wet weather flow inputs for various recurrence interval rainfall events were developed using a ratio of SEWRPC rainfall data to the June 19, 2009 rainfall. The June 19, 2009, event was determined to be approximately a 50-year event (refer to Appendix D for an analysis of the June 19, 2009 rainfall event). The estimated maximum rainfall intensity associated with the June 19, 2009, rainfall event was 3.76 inches/hour.

Table 6.01-6 documents the ratios utilized to scale the peak flow inputs for the June 19, 2009, rainfall event to other rainfall recurrence interval events.

Recurrence Interval	SEWRPC Theoretical Rainfall Rate ¹ (in/hr)	Ratio–SEWRPC Theoretical Rainfall Rate to June 19, 2009 Base Event ²
6-month	1.42	0.384 ³
1-year	1.74	0.470
2-year	2.14	0.578
5-year	2.58	0.697
10-year	2.90	0.784
25-year	3.36	0.908
50-year	3.70	1.000
100-year	4.04	1.092

¹Rainfall rate in inches per hour as published for a rainfall event with a duration of 30 minutes.
²Assumes June 19, 2009, rainfall event recurrence interval of 50 years. Refer to Appendix D.
³Six-month ratio computed as 1.42 ÷ 3.70 = 0.384.

Table 6.01-6 Ratio–June 19, 2009, Rainfall to SEWRPC Theoretical Events

C. Model Calibration

Following the development and distribution to nodes of the dry weather flow inputs, the model was run. Output of the model was reviewed to compare modeled dry weather flows to flow rates metered in the system (including estimated “metered” flow rates as developed in Section 6.01(B)(1). A comparison of total calculated dry weather flow with dry weather model results is presented in Table 6.01-7.

Flow Meter	Location	Peak Calculated Flow (gpm)	Modeled Flow (gpm)
B-7 (MH-5724)	61st Street Between 49th Ave. and 50th Ave.	34	33
B-6 (MH-355)	45th Ave. North of 61st Street	118	116
B-5 (MH-6069)	60th Street East of 45th Ave.	1,134	1129
S-1 (MH-999)	Intersection of 48th Ave. and 65th Street	51	50

Table 6.01-7 Comparison Modeled vs. Metered Flow–Dry Weather

In a similar fashion, wet weather flow inputs were distributed for the June 19, 2009, rainfall event and the model was run. Table 6.01-8 presents a comparison of total calculated wet weather flow with wet weather model results.

Flow Meter	Location	Peak Calculated Flow (gpm)	Modeled Flow (gpm)
B-7 (MH-5724)	61st Street Between 49th Ave. and 50th Ave.	930	931
B-6 (MH-355)	45th Ave. North of 61st Street	1,892	1,912
B-5 (MH-6069)	60th Street East of 45th Ave.	7,072	7,661
S-1 (MH-999)	Intersection of 48th Ave. and 65th Street	1,852	1,897

Table 6.01-8 Comparison of Modeled vs. Metered Flow–Wet Weather


6.02 HYDRAULIC ANALYSIS–EXISTING SANITARY SEWER SYSTEM

Design Storm Evaluation

The hydraulic model was used to model the north and south basin wet weather response to a selection of design storm events. The June 19, 2009, event was used as a base storm event for the model. Tables 6.02-1 and 6.02-2 are a comparison of the peak dry and wet weather data from the June 19, 2009, storm event at each sewer and manhole, including peak flows in sewers and peak water depths in manholes.

The results of the north basin modeling are shown on Figures 6.02-1 through 6.02-8 and listed in Tables 6.02-3 through 6.02-10. The results of the south basin modeling are shown in Figures 6.02-9 through 6.02-16 and listed in Tables 6.02-11 through 6.02-18. One figure and one table were developed for each design storm event for each basin in the study area. The figures show surcharged manholes and sewers where the projected peak flow exceeds the sewer capacity (assumes full pipe flow) for the design rain event. The table associated with each rain event lists surcharge depths in critical manholes, along with a summary of the overall performance of the system.

The north basin modeling results indicate surcharging for all eight modeled design storms. The 6-month and 1-year design storms indicate relatively minor surcharging that may not require conveyance improvements to handle the projected peak flows during those design storms. The 2-year design storm predicts surcharging along 61st Street (between Pershing Boulevard and 46th Street), Pershing Boulevard, and 60th Street with surcharging over 1.0 foot in Pershing Boulevard (MH-354). The 5-year design storm predicts surcharging along 61st Street (between Pershing Boulevard and 50th Street), Pershing Boulevard, and 60th Street with surcharge levels over 2 feet in Pershing Boulevard (MH-355) and 61st Street (MH-5174). The 10-year, 25-year, 50-year, and 100-year design storms predict surcharging along 61st Street, Pershing Boulevard, and 60th Street. Maximum surcharge levels for the 100-year design storm are predicted at approximately 10 feet in MH-672 and MH-5724.




NORTH BASIN - SANITARY SEWER CAPACITY EVALUATION
6-MONTH RECURRENCE INTERVAL EVENT
FOREST PARK AREA STORM AND SANITARY MANAGEMENT PLAN
CITY OF KENOSHA
KENOSHA COUNTY, WISCONSIN



FIGURE 6.02-1
1540.001

S:\MAD\1500-1599\1540\001\Data\GIS Data\Figures\Sewer Analysis\Sewer Analysis 031510\Figure 6.02-1 - 6Month Existing North 11x17.mxd




NORTH BASIN - SANITARY SEWER CAPACITY EVALUATION
1-YEAR RECURRENCE INTERVAL EVENT
FOREST PARK AREA STORM AND SANITARY MANAGEMENT PLAN
CITY OF KENOSHA
KENOSHA COUNTY, WISCONSIN




FIGURE 6.02-2
1540.001

S:\MAD\1500-1599\1540\001\Data\GIS Data\Figures\Sewer Analysis\Sewer Analysis 031510\Figure 6.02-2 - 1Year Existing North 11x17.mxd



Legend

- Manhole Surcharged
- ▶ Projected Peak Flow Exceeds Capacity
- Sanitary Manhole
- ▶ Sanitary Sewer
- Sanitary Sewer Study Limits




NORTH BASIN - SANITARY SEWER CAPACITY EVALUATION
2-YEAR RECURRENCE INTERVAL EVENT
 FOREST PARK AREA STORM AND SANITARY MANAGEMENT PLAN
 CITY OF KENOSHA
 KENOSHA COUNTY, WISCONSIN



FIGURE 6.02-3
1540.001

Legend


- Manhole Surcharged
- ➔ Projected Peak Flow Exceeds Capacity
- Sanitary Manhole
- Sanitary Sewer
- Sanitary Sewer Study Limits



NORTH BASIN - SANITARY SEWER CAPACITY EVALUATION
5-YEAR RECURRENCE INTERVAL EVENT
 FOREST PARK AREA STORM AND SANITARY MANAGEMENT PLAN
 CITY OF KENOSHA
 KENOSHA COUNTY, WISCONSIN



FIGURE 6.02-4
1540.001



NORTH BASIN - SANITARY SEWER CAPACITY EVALUATION
10-YEAR RECURRENCE INTERVAL EVENT
FOREST PARK AREA STORM AND SANITARY MANAGEMENT PLAN
CITY OF KENOSHA
KENOSHA COUNTY, WISCONSIN




FIGURE 6.02-5
1540.001

S:\MAD\1500-1599\1540\001\Data\GIS Data\Figures\Sewer Analysis\Sewer Analysis 031510\Figure 6.02-5 - 10Year Existing North 11x17.mxd

Legend

- Manhole Surcharged
- Projected Peak Flow Exceeds Capacity
- Sanitary Manhole
- Sanitary Sewer
- Sanitary Sewer Study Limits




NORTH BASIN - SANITARY SEWER CAPACITY EVALUATION
25-YEAR RECURRENCE INTERVAL EVENT
FOREST PARK AREA STORM AND SANITARY MANAGEMENT PLAN
CITY OF KENOSHA
KENOSHA COUNTY, WISCONSIN



FIGURE 6.02-6
1540.001

S:\MAD\1500-1599\1540\001\Data\GIS Data\Figures\Sewer Analysis\Sewer Analysis 031510\Figure 6.02-6 - 25Year Existing North 11x17.mxd

- Legend**
- Manhole Surcharged
 - Projected Peak Flow Exceeds Capacity
 - Sanitary Manhole
 - Sanitary Sewer
 - Homes reporting standpipes, plugs or backwater valves (from survey regarding June 19, 2009 storm event)
 - Floor Drain Basement Backup (from survey regarding June 19, 2009 storm event)
 - Sanitary Sewer Study Limits




NORTH BASIN - SANITARY SEWER CAPACITY EVALUATION
50-YEAR RECURRENCE INTERVAL EVENT
 FOREST PARK AREA STORM AND SANITARY MANAGEMENT PLAN
 CITY OF KENOSHA
 KENOSHA COUNTY, WISCONSIN

STRAND
ASSOCIATES, INC.
ENGINEERS

FIGURE 6.02-7
1540.001

Legend


- Manhole Surcharged
- ▶ Projected Peak Flow Exceeds Capacity
- Sanitary Manhole
- ▶ Sanitary Sewer
- Homes reporting standpipes, plugs or backwater valves (from survey regarding June 19, 2009 storm event)
- Floor Drain Basement Backup (from survey regarding June 19, 2009 storm event)
- Sanitary Sewer Study Limits



NORTH BASIN - SANITARY SEWER CAPACITY EVALUATION
100-YEAR RECURRENCE INTERVAL EVENT
FOREST PARK AREA STORM AND SANITARY MANAGEMENT PLAN
CITY OF KENOSHA
KENOSHA COUNTY, WISCONSIN



FIGURE 6.02-8
1540.001




SOUTH BASIN - SANITARY SEWER CAPACITY EVALUATION
1-YEAR RECURRENCE INTERVAL EVENT
FOREST PARK AREA STORM AND SANITARY MANAGEMENT PLAN
CITY OF KENOSHA
KENOSHA COUNTY, WISCONSIN



FIGURE 6.02-10
1540.001

Legend


- Manhole Surcharged
- ➔ Projected Peak Flow Exceeds Capacity
- Sanitary Manhole
- ➔ Sanitary Sewer
- Sanitary Sewer Study Limits



SOUTH BASIN - SANITARY SEWER CAPACITY EVALUATION
2-YEAR RECURRENCE INTERVAL EVENT
FOREST PARK AREA STORM AND SANITARY MANAGEMENT PLAN
CITY OF KENOSHA
KENOSHA COUNTY, WISCONSIN



FIGURE 6.02-11
1540.001




SOUTH BASIN - SANITARY SEWER CAPACITY EVALUATION
5-YEAR RECURRENCE INTERVAL EVENT
FOREST PARK AREA STORM AND SANITARY MANAGEMENT PLAN
CITY OF KENOSHA
KENOSHA COUNTY, WISCONSIN



FIGURE 6.02-12
1540.001

Legend

- Manhole Surcharged
- ➔ Projected Peak Flow Exceeds Capacity
- Sanitary Manhole
- ➔ Sanitary Sewer
- ▨ Homes reporting standpipes, plugs or backwater valves (from survey regarding June 19, 2009 storm event)
- ▨ Floor Drain Basement Backup (from survey regarding June 19, 2009 storm event)
- ▭ Sanitary Sewer Study Limits



SOUTH BASIN - SANITARY SEWER CAPACITY EVALUATION
100-YEAR RECURRENCE INTERVAL EVENT
FOREST PARK AREA STORM AND SANITARY MANAGEMENT PLAN
CITY OF KENOSHA
KENOSHA COUNTY, WISCONSIN



FIGURE 6.02-16
1540.001

The south basin modeling results indicate surcharging for five of the eight modeled design storms. Surcharging is not predicted for the 6-month, 1-year, and 2-year design storms. The 5-, 10-, 25-, 50-, and 100-year design storms model higher levels of surcharging. The surcharging generally occurs along 65th street from 48th Avenue to 51st Avenue. The maximum surcharge level for the 100-year design storm is modeled at 7.7 feet in MH-2630.

Figures 6.02-7, 6.02-8, 6.02-15, and 6.02-16 also show the homes that reported (June 2009 survey) having a backwater valve, standpipe, or plug installed. Had these devices not been installed, it is likely the flooding in both basins would have impacted additional homes.

A complete printout of manhole and pipe results for the model runs associated with the various design storms can be found in Appendix E.

TABLE 6.02-1

JUNE 19, 2009, BASE RAINFALL EVENT—COMPARISON OF PEAK AND DRY WEATHER FLOW RATES NORTH BASIN

Conduit (Pipe) Summary - Dry Weather vs. June 19, 2009 Rainfall Event							Junction (Manhole) Summary - Dry Weather vs. June 19, 2009 Rainfall Event							
Conduit Name	Dry Weather		Wet Weather		Difference in Peak Flow (cfs)	Difference in Total Flow (ft ³)	Junction Name	Dry Weather			Wet Weather			Change in Maximum Elevation (ft)
	Peak Flow (cfs)	Total Flow (ft ³)	Peak Flow (cfs)	Total Flow (ft ³)				Invert Elevation (ft)	Maximum Elevation (ft)	Difference in Elevation (ft)	Invert Elevation (ft)	Maximum Elevation (ft)	Difference in Elevation (ft)	
P-485	0.011	2,845	0.321	17,583	0.310	14,737	MH-1002	678.59	678.59	0.00	678.59	678.59	0.00	0.00
P-486	0.011	2,843	0.407	17,579	0.396	14,736	MH-1003	670.22	670.29	0.07	670.22	670.44	0.22	0.15
P-487	0.011	2,838	0.360	17,568	0.350	14,729	MH-1004	679.20	679.24	0.04	679.20	679.34	0.14	0.09
P-671	0.055	14,611	1.549	90,391	1.495	75,780	MH-16339	670.60	677.47	6.87	670.60	677.57	6.97	0.10
P-2983	0.074	19,811	2.088	122,244	2.014	102,433	MH-16365	685.47	685.54	0.07	685.47	685.82	0.35	0.28
P-2985	0.074	19,801	2.086	122,232	2.012	102,431	MH-16366	683.15	683.19	0.04	683.15	683.38	0.23	0.19
P-2981	0.111	29,849	2.516	152,767	2.405	122,919	MH-16369	660.52	660.67	0.15	660.52	666.15	5.63	5.49
P-2979	0.111	29,833	2.516	152,759	2.405	122,926	MH-1822	675.04	675.08	0.04	675.04	677.26	2.22	2.18
P-521	0.150	40,052	2.965	184,204	2.816	144,152	MH-1823	682.14	682.17	0.03	682.14	682.30	0.16	0.13
P-522	0.150	40,040	2.970	184,194	2.820	144,153	MH-1824	688.94	689.27	0.33	688.94	689.42	0.48	0.15
P-2909	0.196	52,545	3.514	222,305	3.318	169,761	MH-1885	686.34	686.40	0.06	686.34	686.67	0.33	0.27
P-2910	0.196	52,534	3.515	222,293	3.318	169,760	MH-1886	687.93	687.97	0.04	687.93	688.13	0.20	0.16
P-2915	0.219	58,429	2.071	204,359	1.853	145,930	MH-1888	689.51	689.55	0.04	689.51	689.71	0.20	0.16
P-2916	0.219	58,402	2.062	204,343	1.843	145,941	MH-1891	672.49	672.57	0.09	672.49	679.03	6.54	6.45
P-195	0.238	63,696	3.162	248,385	2.923	184,689	MH-1893	680.52	680.56	0.04	680.52	680.72	0.20	0.17
P-196	0.238	63,675	3.163	248,375	2.925	184,700	MH-1895	683.92	683.97	0.05	683.92	684.15	0.23	0.19
P-506	0.010	2,754	0.307	16,790	0.296	14,036	MH-3088	688.42	688.45	0.03	688.42	688.58	0.16	0.12
P-507	0.010	2,748	0.380	16,779	0.370	14,031	MH-3089	689.52	689.57	0.05	689.52	689.75	0.23	0.18
P-501	0.009	2,280	0.260	14,210	0.251	11,930	MH-3090	690.25	690.28	0.03	690.25	690.42	0.17	0.14
P-502	0.009	2,277	0.259	14,208	0.251	11,931	MH-320	642.91	643.44	0.53	642.91	644.24	1.33	0.80
P-503	0.015	3,881	0.441	24,236	0.427	20,355	MH-343	644.54	645.34	0.80	644.54	648.59	4.05	3.25
P-504	0.014	3,873	0.441	24,231	0.426	20,358	MH-354	649.05	649.30	0.25	649.05	652.38	3.33	3.08
P-899	0.006	1,615	0.183	10,036	0.177	8,421	MH-355	651.27	651.45	0.18	651.27	655.48	4.21	4.03
P-901	0.006	1,612	0.183	10,034	0.177	8,422	MH-356	653.87	654.05	0.18	653.87	659.04	5.17	4.99
P-904	0.006	1,610	0.183	10,032	0.177	8,422	MH-357	651.50	651.59	0.09	651.50	652.02	0.52	0.43
P-265	0.002	570	0.061	3,377	0.059	2,807	MH-358	657.67	657.72	0.05	657.67	658.00	0.33	0.28
P-266	0.022	5,962	0.749	36,844	0.727	30,882	MH-374	655.17	655.40	0.23	655.17	660.15	4.98	4.76
P-505	0.022	5,958	0.657	36,842	0.635	30,884	MH-375	656.42	656.48	0.06	656.42	659.36	2.94	2.88
P-267	0.038	10,223	1.116	62,860	1.078	52,638	MH-396	656.07	656.15	0.08	656.07	660.20	4.13	4.05
P-268	0.038	10,215	1.106	62,851	1.068	52,636	MH-4199	674.91	675.30	0.39	674.91	676.01	1.10	0.71
P-261	0.006	1,613	0.181	10,029	0.175	8,416	MH-466	662.54	662.59	0.05	662.54	662.68	0.14	0.09
P-262	0.006	1,610	0.296	10,027	0.290	8,416	MH-467	669.02	669.07	0.05	669.02	669.17	0.15	0.11
P-269	0.013	3,325	0.367	20,168	0.354	16,843	MH-468	678.62	678.67	0.05	678.62	678.78	0.16	0.11
P-270	0.012	3,323	0.418	20,166	0.406	16,842	MH-470	660.35	660.41	0.06	660.35	660.55	0.20	0.14
P-271	0.012	3,321	0.390	20,158	0.378	16,837	MH-471	669.63	669.67	0.04	669.63	669.77	0.14	0.09
P-263	0.007	1,900	0.295	11,724	0.288	9,824	MH-472	672.62	672.67	0.05	672.62	672.78	0.16	0.11
P-264	0.007	1,898	0.295	11,717	0.288	9,819	MH-5152	657.82	657.96	0.15	657.82	663.28	5.47	5.32
P-272	0.014	3,610	0.279	10,928	0.266	7,317	MH-5174	654.42	654.77	0.35	654.42	659.60	5.18	4.84
P-273	0.014	3,605	0.248	10,918	0.234	7,313	MH-5568	645.49	645.68	0.19	645.49	646.65	1.16	0.97
P-259	0.024	6,460	0.344	19,624	0.320	13,164	MH-5571	647.10	647.30	0.20	647.10	648.53	1.43	1.22
P-260	0.024	6,456	0.335	19,622	0.311	13,166	MH-5572	651.17	651.17	0.00	651.17	651.77	0.60	0.60
P-278	0.023	6,079	0.281	18,521	0.258	12,441	MH-5574	649.86	650.30	0.44	649.86	652.58	2.72	2.28
P-277	0.023	5,976	0.281	18,417	0.258	12,442	MH-5724	666.50	666.61	0.11	666.50	674.98	8.48	8.37
P-283	0.023	5,966	0.324	18,406	0.301	12,440	MH-6069	644.22	644.80	0.58	644.22	646.66	2.44	1.86
P-284	0.000	-	0.000	-	0.000	-	MH-6075	664.66	665.01	0.35	664.66	665.62	0.96	0.60
P-257	0.016	4,275	0.198	13,057	0.182	8,782	MH-6090	648.12	648.30	0.18	648.12	648.96	0.84	0.65
P-258	0.016	4,270	0.198	13,053	0.182	8,783	MH-6092	669.68	669.72	0.04	669.68	669.79	0.11	0.07
P-308	0.023	6,081	0.281	18,523	0.258	12,441	MH-6168	649.80	649.89	0.09	649.80	650.41	0.61	0.52
P-311	0.023	6,074	0.280	18,516	0.258	12,442	MH-669	669.72	669.98	0.26	669.72	677.12	7.40	7.15
P-276	0.023	6,067	0.273	18,503	0.251	12,435	MH-670	670.64	670.68	0.04	670.64	677.16	6.52	6.48
P-275	0.024	6,447	0.296	19,624	0.272	13,177	MH-671	672.22	672.26	0.04	672.22	677.19	4.97	4.93
P-208	0.021	5,699	0.264	17,409	0.243	11,710	MH-672	667.61	667.73	0.12	667.61	676.02	8.41	8.29
P-207	0.021	5,697	0.264	17,408	0.243	11,710	MH-673	674.22	674.25	0.03	674.22	676.06	1.84	1.81
P-205	0.021	5,695	0.297	17,404	0.275	11,710	MH-674	680.96	680.99	0.03	680.96	681.10	0.14	0.11
P-204	0.021	5,689	0.263	17,401	0.241	11,712	MH-871	669.42	669.50	0.08	669.42	673.91	4.49	4.41
P-199	0.002	234	-0.842	(7,560)	-0.843	(7,794)	MH-877	673.92	673.98	0.06	673.92	674.21	0.29	0.23
P-202	0.001	232	-0.842	(7,554)	-0.843	(7,786)	MH-879	665.37	665.53	0.16	665.37	673.83	8.46	8.30
P-211	0.020	5,321	0.248	16,299	0.228	10,978	MH-884	664.16	664.30	0.14	664.16	670.59	6.43	6.29
P-209	0.020	5,319	0.248	16,297	0.228	10,978	MH-886	676.44	676.49	0.05	676.44	676.59	0.15	0.10
P-210	0.020	5,312	0.251	16,289	0.231	10,977	MH-887	681.39	681.44	0.05	681.39	681.54	0.15	0.10
P-3077	2.527	673,809	17.094	1,391,022	14.567	717,213	MH-937	671.56	671.65	0.09	671.56	678.35	6.79	6.71
P-3073	2.525	673,672	17.095	1,390,903	14.570	717,231	MH-938	673.51	673.58	0.07	673.51	679.29	5.78	5.72
P-3067	2.525	673,606	12.370	1,352,138	9.845	678,533	MH-940	688.29	688.30	0.01	688.29	688.35	0.06	0.05
P-3069	2.523	673,402	12.370	1,351,962	9.846	678,560	MH-943	673.68	673.72	0.04	673.68	676.18	2.50	2.46
P-3070	2.523	673,311	12.370	1,351,888	9.847	678,577	MH-944	677.68	677.72	0.04	677.68	677.87	0.19	0.15
P-3088	0.024	6,461	0.198	13,058	0.174	6,597	MH-946	681.69	681.73	0.04	681.69	681.89	0.20	0.16
P-3092	0.045	12,301	1.299	39,128	1.254	26,828	MH-961	667.79	667.84	0.05	667.79	673.86	6.07	6.01
P-3093	0.045	12,296	1.301	39,123	1.256	26,828	MH-962	679.79	679.82	0.03	679.79	679.89	0.10	0.06
P-17061	0.282	75,923	4.466	287,466	4.183	211,543	MH-968	667.62	667.73	0.11	667.62	667.93	0.31	0.21
P-2956	0.000	-	4.716	38,703	4.716	38,703	MH-969	668.42	668.51	0.09	668.42	668.70	0.28	0.20
P-2957	0.000	-	4.714	38,706	4.714	38,706	MH-976	663.37	663.44	0.07	663.37	666.25	2.88	2.81
P-2958	0.282	75,896	9.011	326,159	8.729	250,263	MH-983	662.32	662.49	0.17	662.32	668.50	6.18	6.00
P-197	0.238	63,644	3.165	248,351	2.927	184,707	MH-986	664.80	664.97	0.17	664.80	672.38	7.58	7.41
P-274	0.024	6,457	0.297	19,630	0.273	13,173	MH-991	670.54	670.65	0.11	670.54	670.91	0.37	0.25
P-2917	0.000	-	1.469	27,750	1.469	27,750	MH-9							

TABLE 6.02-2

JUNE 19, 2009, BASE RAINFALL EVENT—COMPARISON OF PEAK AND DRY WEATHER FLOW RATES SOUTH BASIN

Conduit (Pipe) Summary - Dry Weather vs. June 19, 2009 Rainfall Event							Junction (Manhole) Summary - Dry Weather vs. June 19, 2009 Rainfall Event							
Conduit Name	Dry Weather		Wet Weather		Difference in Peak Flow (cfs)	Difference in Total Flow (ft ³)	Junction Name	Dry Weather			Wet Weather			Change in Maximum Elevation (ft)
	Peak Flow (cfs)	Total Flow (ft ³)	Peak Flow (cfs)	Total Flow (ft ³)				Invert Elevation (ft)	Maximum Elevation (ft)	Difference in Elevation (ft)	Invert Elevation (ft)	Maximum Elevation (ft)	Difference in Elevation (ft)	
P-795	0.001	154	0.025	1336	0.024	1,183	MH-993	681.42	681.46	0.04	681.42	681.65	0.23	0.19
P-796	0.001	304	0.042	2331	0.041	2,027	MH-999	672.26	672.39	0.13	672.26	672.99	0.73	0.60
P-797	0.012	2700	0.508	25086	0.497	22,387	MH-1001	678.42	678.45	0.03	678.42	678.58	0.16	0.13
P-798	0.012	2696	0.507	25084	0.495	22,387	MH-2496	674.80	674.95	0.15	674.80	679.45	4.65	4.49
P-799	0.012	2693	0.532	25081	0.521	22,388	MH-2497	677.12	677.18	0.06	677.12	679.74	2.62	2.56
P-800	0.011	2689	0.560	25077	0.549	22,388	MH-2499	678.62	678.68	0.06	678.62	680.05	1.43	1.37
P-587	0.048	11299	1.863	102988	1.815	91,689	MH-2507	679.79	679.85	0.06	679.79	680.31	0.52	0.46
P-589	0.048	11293	1.869	102979	1.821	91,685	MH-2592	675.72	675.84	0.12	675.72	681.46	5.74	5.62
P-591	0.081	18987	3.072	172729	2.991	153,742	MH-2594	676.67	676.79	0.12	676.67	683.44	6.77	6.65
P-592	0.081	18979	3.074	172725	2.993	153,746	MH-2598	679.86	679.91	0.05	679.86	683.68	3.82	3.77
P-594	0.103	24288	3.903	220458	3.800	196,170	MH-2599	681.74	681.79	0.05	681.74	683.93	2.19	2.14
P-596	0.103	24281	3.903	220443	3.800	196,162	MH-2610	683.62	683.67	0.05	683.62	684.18	0.56	0.51
P-1055	0.119	27967	4.494	253839	4.376	225,872	MH-2630	677.62	677.72	0.10	677.62	684.17	6.55	6.46
P-1056	0.118	27942	4.494	253863	4.376	225,921	MH-2631	678.49	678.59	0.10	678.49	684.89	6.40	6.30
P-1057	0.118	27928	4.494	253850	4.376	225,922	MH-2645	673.92	674.04	0.12	673.92	676.09	2.17	2.06
P-281	0.008	1931	0.325	17446	0.316	15,514	MH-2707	687.24	687.29	0.05	687.24	687.52	0.28	0.23
P-282	0.008	1929	0.324	17443	0.316	15,514	MH-2709	688.55	688.60	0.05	688.55	688.84	0.29	0.24
P-525	0.014	3246	0.535	29107	0.521	25,862	MH-2743	689.81	689.87	0.06	689.81	690.12	0.31	0.26
P-536	0.014	3242	0.525	29104	0.511	25,862	MH-2831	677.62	677.69	0.07	677.62	683.65	6.03	5.95
P-538	0.014	3237	0.521	29097	0.507	25,861	MH-2833	679.94	680.00	0.06	679.94	684.22	4.28	4.22
P-739	0.009	2086	0.341	18640	0.332	16,554	MH-2835	680.34	680.40	0.06	680.34	684.32	3.98	3.92
P-737	0.009	2081	0.336	18634	0.327	16,553	MH-2836	681.30	681.35	0.05	681.30	684.43	3.13	3.08
P-565	0.014	3246	0.537	29107	0.523	25,861	MH-2839	675.72	675.77	0.05	675.72	679.48	3.76	3.70
P-569	0.014	3243	0.528	29103	0.514	25,860	MH-2840	676.34	676.39	0.05	676.34	679.51	3.17	3.12
P-571	0.014	3239	0.521	29095	0.507	25,857	MH-2895	681.82	681.88	0.06	681.82	684.51	2.69	2.63
P-766	0.010	2319	0.462	20933	0.452	18,615	MH-2898	686.93	686.96	0.03	686.93	687.11	0.18	0.14
P-768	0.010	2316	0.396	20933	0.386	18,616	MH-2920	681.86	681.92	0.06	681.86	685.86	4.00	3.94
P-681	0.010	2314	0.382	20931	0.372	18,617	MH-2921	683.02	683.04	0.02	683.02	685.88	2.86	2.84
P-683	0.010	2311	0.405	20928	0.395	18,616	MH-2922	689.61	689.62	0.01	689.61	689.69	0.08	0.07
P-692	0.019	4474	0.726	40664	0.707	36,190	MH-2933	683.30	684.03	0.73	683.30	685.89	2.59	1.87
P-693	0.019	4468	0.723	40660	0.704	36,192	MH-2939	694.42	694.43	0.01	694.42	694.49	0.07	0.06
P-263	0.012	2859	0.476	25621	0.464	22,762	MH-2960	691.21	691.22	0.01	691.21	691.29	0.08	0.07
P-610	0.012	2857	0.476	25619	0.464	22,763	MH-2975	679.38	679.44	0.06	679.38	685.14	5.76	5.70
P-611	0.012	2853	0.476	25616	0.463	22,763	MH-2976	680.26	680.32	0.06	680.26	685.39	5.13	5.07
P-833	0.007	1545	0.260	13956	0.253	12,411	MH-2978	681.06	681.12	0.06	681.06	685.61	4.55	4.50
P-835	0.007	1543	0.260	13954	0.253	12,412	MH-3072	688.71	688.78	0.07	688.71	689.11	0.40	0.33
P-837	0.007	1541	0.259	13952	0.253	12,411	MH-3073	689.79	689.85	0.06	689.79	690.16	0.37	0.31
P-841	0.007	1538	0.259	13949	0.253	12,411	MH-3074	690.67	690.73	0.06	690.67	691.04	0.37	0.31
P-844	0.015	3469	0.582	31393	0.567	27,924	MH-3075	693.74	693.77	0.03	693.74	693.93	0.19	0.15
P-845	0.015	3465	0.582	31391	0.567	27,926	MH-3076	695.95	695.98	0.03	695.95	696.14	0.19	0.15
P-1996	0.015	3461	0.582	31387	0.567	27,926	MH-3078	698.15	698.18	0.03	698.15	698.34	0.19	0.16
P-864	0.015	3460	0.582	31384	0.567	27,924	MH-3079	700.61	700.64	0.03	700.61	700.80	0.19	0.16
P-872	0.015	3457	0.571	31375	0.556	27,918	MH-3080	680.42	680.49	0.07	680.42	685.53	5.11	5.04
P-873	0.010	2319	0.397	20933	0.387	18,614	MH-3081	682.12	682.19	0.07	682.12	686.22	4.10	4.03
P-876	0.024	5772	0.946	52310	0.921	46,538	MH-3082	683.76	683.83	0.07	683.76	686.96	3.20	3.13
P-881	0.024	5769	0.937	52307	0.913	46,538	MH-3083	686.41	686.45	0.04	686.41	687.03	0.62	0.58
P-883	0.024	5763	0.928	52299	0.904	46,536	MH-3086	686.46	686.51	0.05	686.46	687.21	0.75	0.70
P-792	0.001	154	0.026	1404	0.025	1,250	MH-3087	687.81	687.86	0.05	687.81	688.09	0.28	0.23
P-788	0.001	152	0.026	1401	0.025	1,248	MH-3200	671.09	671.23	0.14	671.09	671.83	0.74	0.60
P-2328	0.000	77	0.109	956	0.108	878	MH-3204	668.99	669.13	0.14	668.99	669.75	0.76	0.62
P-786	0.001	235	0.204	3020	0.202	2,786	MH-3207	669.76	669.89	0.13	669.76	670.48	0.72	0.58
P-17598	0.000	77	0.009	500	0.009	423	MH-4634	692.92	692.92	0.00	692.92	692.95	0.03	0.03
P-17599	0.000	77	0.009	500	0.009	423	MH-16260	694.21	694.23	0.02	694.21	694.29	0.08	0.06
P-17600	0.000	77	0.009	499	0.008	423	MH-16261	694.71	694.72	0.01	694.71	694.77	0.06	0.05
P-17601	0.000	77	0.009	500	0.009	423	MH-16262	695.61	695.62	0.01	695.61	695.65	0.04	0.04
P-17602	0.001	153	0.017	998	0.017	845	MH-16263	695.91	695.92	0.01	695.91	695.95	0.04	0.04
P-17604	0.001	152	0.017	997	0.017	845	MH-16264	696.40	696.41	0.01	696.40	696.44	0.04	0.03
P-783	0.000	6	0.122	987	0.122	980	MH-16265	696.84	696.85	0.01	696.84	696.89	0.05	0.04
P-287	0.004	1003	0.166	8930	0.161	7,926	MH-16266	691.66	691.68	0.02	691.66	691.76	0.10	0.08
P-1888	0.008	1775	0.298	16034	0.290	14,259	MH-635	668.62	668.67	0.05	668.62	668.89	0.27	0.22
P-1887	0.008	1770	0.298	16031	0.290	14,260	MH-1005	671.40	671.44	0.04	671.40	671.62	0.22	0.18
P-1885	0.000	0	0.000	0	0.000	0	MH-1006	680.42	680.45	0.03	680.42	680.57	0.15	0.12
P-1884	0.000	0	0.000	0	0.000	0	MH-2646	672.32	672.32	0.00	672.32	672.32	0.00	0.00
P-2991	0.000	0	0.000	0	0.000	0	MH-4319	670.11	670.11	0.00	670.11	670.11	0.00	0.00
P-600	0.000	0	0.000	0	0.000	0	MH-4320	671.59	671.59	0.00	671.59	671.59	0.00	0.00
P-601	0.000	0	0.000	0	0.000	0	MH-4321	670.02	670.06	0.04	670.02	670.24	0.22	0.18
P-1059	0.121	28596	4.605	260064	4.484	231,469	MH-604	666.32	666.38	0.06	666.32	666.64	0.32	0.27
P-1060	0.130	30666	4.943	278757	4.813	248,091	MH-634	667.43	667.48	0.05	667.43	667.71	0.28	0.23
P-1061	0.130	30656	4.943	278748	4.813	248,092	MH-2841	667.25	667.37	0.12	667.25	667.95	0.70	0.58
P-1062	0.130	30630	4.943	278715	4.813	248,085	MH-2842	674.07	674.11	0.04	674.07	674.27	0.20	0.16
P-1943	0.005	1080	0.182	9790	0.177	8,710	MH-2843	674.88	674.92	0.03	674.88	675.07	0.19	0.16
P-1944	0.005	1074	0.182	9786	0.177	8,712	MH-3208	663.88	664.00	0.12	663.88	664.57	0.69	0.57
P-753	0.004	1004	0.166	8930	0.161	7,926	MH-3209	665.65	665.78	0.13	665.65	666.34	0.69	0.57
P-760	0.004	1000	0.165	8929	0.161	7,928	MH-3210	666.68	666.81	0.13	666.68	667.39	0.71	0.58
P-254	0.012	2851	0.479	25823	0.467	22,972	MH-4343	673.09	673.41	0.32	673.09	673.58	0.49	0.17
P-255	0.012	2848	0.479	25820	0.467	22,972	MH-4344	674.52	674.56	0.04	674.52	674.72	0.20	0.17

**TABLE 6.02-3
 6-MONTH RECURRENCE INTERVAL MANHOLE/PIPE SURCHARGE SUMMARY NORTH BASIN**

Location	Description
Pershing Boulevard	<ul style="list-style-type: none"> ▪ Minor surcharging of 0.06 feet in MH-354. ▪ Pipe segment P-197 projected peak flow equals full gravity capacity.
61st Street	<ul style="list-style-type: none"> ▪ Pipe Segments P-2915 and P-2916 projected peak flow is full gravity capacity.

**TABLE 6.02-4
 1-YEAR RECURRENCE INTERVAL MANHOLE/PIPE SURCHARGE SUMMARY NORTH BASIN**

Location	Description
Pershing Boulevard	<ul style="list-style-type: none"> ▪ Minor surcharging of 0.51 feet in MH-354. ▪ Pipe segment P-197 projected peak flow is 1.2 times full gravity capacity.
61st Street	<ul style="list-style-type: none"> ▪ Minor surcharging of 0.29 feet in MH-5174. ▪ Pipe Segments P-2915-and P-2916 projected peak flow is 1.2 times the full gravity capacity.

**TABLE 6.02-5
 2-YEAR RECURRENCE INTERVAL MANHOLE/PIPE SURCHARGE SUMMARY NORTH BASIN**

Location	Description
Pershing Boulevard	<ul style="list-style-type: none"> ▪ Surcharging of 1.13 feet and 0.94 feet in MH-354 and MH-355, respectively. ▪ Pipe segment P-197 projected peak flow is 1.5 times full gravity capacity.
61st Street	<ul style="list-style-type: none"> ▪ Surcharging of 0.88 feet in MH-5174. ▪ Surcharging of 0.01 feet in MH-986. ▪ Pipe Segments P-2915-and P-2916 projected peak flow is 1.3 times the full gravity capacity.
60th Street	<ul style="list-style-type: none"> ▪ Surcharging of 0.42 feet in MH-6069. ▪ Pipe Segment P-3069 projected peak flow is 2.0 times the full gravity capacity.
46th Avenue	<ul style="list-style-type: none"> ▪ Minor surcharging of 0.33 feet in MH-396.

**TABLE 6.02-6
 5-YEAR RECURRENCE INTERVAL MANHOLE/PIPE SURCHARGE SUMMARY NORTH BASIN**

Location	Description
Pershing Boulevard	<ul style="list-style-type: none"> ▪ A maximum surcharge depth of 2.02 feet in MH-355. ▪ Pipe segment P-197 projected peak flow is 1.7 times full gravity capacity.
61st Street	<ul style="list-style-type: none"> ▪ A maximum surcharge depth of 2.16 feet in MH-5174. ▪ A maximum surcharge depth of 0.34 feet in MH-879. ▪ Pipe Segments P-2915-and P-2916 projected peak flow is 1.3 times the full gravity capacity.
60th Street	<ul style="list-style-type: none"> ▪ Surcharging of 0.57 feet in MH-6069. ▪ Pipe Segment P-3069 projected peak flow is 2.1 times the full gravity capacity.
46th Avenue	<ul style="list-style-type: none"> ▪ Surcharging of 1.26 feet in MH-396.

**TABLE 6.02-7
 10-YEAR RECURRENCE INTERVAL MANHOLE/PIPE SURCHARGE SUMMARY NORTH BASIN**

Location	Description
Pershing Boulevard	<ul style="list-style-type: none"> ▪ A maximum surcharge depth of 2.33 feet in MH-355. ▪ Pipe segment P-197 projected peak flow is 1.7 times full gravity capacity.
61st Street	<ul style="list-style-type: none"> ▪ A maximum surcharge depth of 2.64 feet in MH-5174. ▪ A maximum surcharge depth of 1.63 feet in MH-879. ▪ A maximum surcharge depth of 0.98 feet in MH-374. ▪ Pipe Segments P-2915-and P-2916 projected peak flow is 1.3 times the full gravity capacity. ▪ Pipe Segments P-2981-and P-2979 projected peak flow is 1.3 times the full gravity capacity.
60th Street	<ul style="list-style-type: none"> ▪ Surcharging of 0.65 feet in MH-6069. ▪ Pipe Segment P-3069 projected peak flow is 2.1 times the full gravity capacity.
46th Avenue	<ul style="list-style-type: none"> ▪ Surcharging of 1.77 feet in MH-396.

**TABLE 6.02-8
 25-YEAR RECURRENCE INTERVAL MANHOLE/PIPE SURCHARGE SUMMARY NORTH BASIN**

Location	Description
Pershing Boulevard	<ul style="list-style-type: none"> ▪ A maximum surcharge depth of 2.87 feet in MH-355. ▪ Pipe segment P-197 projected peak flow is 1.8 times full gravity capacity.
61st Street	<ul style="list-style-type: none"> ▪ A maximum surcharge depth of 3.49 feet in MH-5174. ▪ A maximum surcharge depth of 4.79 feet in MH-879. ▪ A maximum surcharge depth of 1.87 feet in MH-374. ▪ A maximum surcharge depth of 4.96 feet in MH-5724. ▪ Pipe Segments P-2915-and P-2916 projected peak flow is 1.3 times the full gravity capacity. ▪ Pipe Segments P-2981-and P-2979 projected peak flow is 1.5 times the full gravity capacity.
60th Street	<ul style="list-style-type: none"> ▪ Surcharging of 0.77 feet in MH-6069. ▪ Pipe Segment P-3069 projected peak flow is 2.1 times the full gravity capacity.
46th Avenue	<ul style="list-style-type: none"> ▪ Surcharging of 2.67 feet in MH-396.
51st Avenue	<ul style="list-style-type: none"> ▪ Surcharging of 3.03 feet in MH-937.

**TABLE 6.02-9
 50-YEAR RECURRENCE INTERVAL MANHOLE/PIPE SURCHARGE SUMMARY NORTH BASIN**

Location	Description
Pershing Boulevard	<ul style="list-style-type: none"> ▪ A maximum surcharge depth of 3.38 feet in MH-355. ▪ Pipe segment P-197 projected peak flow is 1.9 times full gravity capacity.
61st Street	<ul style="list-style-type: none"> ▪ A maximum surcharge depth of 4.25 feet in MH-5174. ▪ A maximum surcharge depth of 7.34 feet in MH-879. ▪ A maximum surcharge depth of 2.65 feet in MH-374. ▪ A maximum surcharge depth of 7.65 feet in MH-5724. ▪ Pipe Segments P-2915-and P-2916 projected peak flow is 1.3 times the full gravity capacity. ▪ Pipe Segments P-2981-and P-2979 projected peak flow is 1.6 times the full gravity capacity.
60th Street	<ul style="list-style-type: none"> ▪ Surcharging of 0.94 feet in MH-6069. ▪ Pipe Segment P-3069 projected peak flow is 2.2 times the full gravity capacity.
46th Avenue	<ul style="list-style-type: none"> ▪ Surcharging of 3.46 feet in MH-396.
51st Avenue	<ul style="list-style-type: none"> ▪ Surcharging of 6.12 feet in MH-937.

**TABLE 6.02-10
 100-YEAR RECURRENCE INTERVAL MANHOLE/PIPE SURCHARGE SUMMARY NORTH BASIN**

Location	Description
Pershing Boulevard	<ul style="list-style-type: none"> ▪ A maximum surcharge depth of 8.55 feet in MH-355. ▪ Pipe segment P-197 projected peak flow is 2.0 times full gravity capacity.
61st Street	<ul style="list-style-type: none"> ▪ A maximum surcharge depth of 9.73 feet in MH-5174. ▪ A maximum surcharge depth of 10.05 feet in MH-879. ▪ A maximum surcharge depth of 8.10 feet in MH-374. ▪ A maximum surcharge depth of 10.0 feet in MH-5724. ▪ Pipe Segments P-2915-and P-2916 projected peak flow is 1.3 times the full gravity capacity. ▪ Pipe Segments P-2981-and P-2979 projected peak flow is 1.7 times the full gravity capacity.
60th Street	<ul style="list-style-type: none"> ▪ Surcharging of 3.29 feet in MH-6069. ▪ Pipe Segment P-3069 projected peak flow is 2.3 times the full gravity capacity.
46th Avenue	<ul style="list-style-type: none"> ▪ Surcharging of 9.03 feet in MH-396.
51st Avenue	<ul style="list-style-type: none"> ▪ Surcharging of 8.57 feet in MH-937.

**TABLE 6.02-11
 6-MONTH RECURRENCE INTERVAL MANHOLE/PIPE SURCHARGE SUMMARY SOUTH BASIN**

Location	Description
	No Surcharging Modeled

**TABLE 6.02-12
 1-YEAR RECURRENCE INTERVAL MANHOLE/PIPE SURCHARGE SUMMARY SOUTH BASIN**

Location	Description
	No Surcharging Modeled

**TABLE 6.02-13
 2-YEAR RECURRENCE INTERVAL MANHOLE/PIPE SURCHARGE SUMMARY SOUTH BASIN**

Location	Description
65th Street	<ul style="list-style-type: none"> ▪ Pipe segment P-594 projected peak flow is 1.2 times full gravity capacity.

**TABLE 6.02-14
 5-YEAR RECURRENCE INTERVAL MANHOLE/PIPE SURCHARGE SUMMARY SOUTH BASIN**

Location	Description
65th Street	<ul style="list-style-type: none"> ▪ Surcharging of 0.93 feet in MH-2592. ▪ Pipe segment P-592 projected peak flow is 1.1 times full gravity capacity. ▪ Surcharging of 0.52 feet in MH-2630. ▪ Pipe segment P-591 projected peak flow is 1.1 times full gravity capacity. ▪ Pipe segment P-594 projected peak flow is 1.4 times full gravity capacity.

**TABLE 6.02-15
 10-YEAR RECURRENCE INTERVAL MANHOLE/PIPE SURCHARGE SUMMARY SOUTH BASIN**

Location	Description
65th Street	<ul style="list-style-type: none"> ▪ Surcharging of 1.81 feet in MH-2592. ▪ Pipe segment P-592 projected peak flow is 1.2 times full gravity capacity. ▪ Surcharging of 1.36 feet in MH-2594. ▪ Pipe segment P-591 projected peak flow is 1.2 times full gravity capacity. ▪ Surcharging of 1.72 feet in MH-2630. ▪ Pipe segment P-594 projected peak flow is 1.6 times full gravity capacity.
50th Avenue	<ul style="list-style-type: none"> ▪ Surcharging of 1.39 feet in MH-2831.

**TABLE 6.02-16
 25-YEAR RECURRENCE INTERVAL MANHOLE/PIPE SURCHARGE SUMMARY SOUTH BASIN**

Location	Description
65th Street	<ul style="list-style-type: none"> ▪ Surcharging of 3.49 feet in MH-2592. ▪ Pipe segment P-592 projected peak flow is 1.4 times full gravity capacity. ▪ Surcharging of 3.36 feet in MH-2594. ▪ Pipe segment P-591 projected peak flow is 1.4 times full gravity capacity. ▪ Surcharging of 2.10 feet in MH-2496. ▪ Pipe segment P-594 projected peak flow is 1.8 times full gravity capacity.
50th Avenue	<ul style="list-style-type: none"> ▪ Surcharging of 3.43 feet in MH-2831.

**TABLE 6.02-17
 50-YEAR RECURRENCE INTERVAL MANHOLE/PIPE SURCHARGE SUMMARY SOUTH BASIN**

Location	Description
65th Street	<ul style="list-style-type: none"> ▪ Surcharging of 4.91 feet in MH-2592. ▪ Pipe segment P-592 projected peak flow is 1.5 times full gravity capacity. ▪ Surcharging of 5.10 feet in MH-2594. ▪ Pipe segment P-591 projected peak flow is 1.5 times full gravity capacity. ▪ Surcharging of 5.72 feet in MH-2630. ▪ Pipe segment P-594 projected peak flow is 2.0 times full gravity capacity.
51st Avenue	<ul style="list-style-type: none"> ▪ Surcharging of 4.44 feet in MH-3080.
50th Avenue	<ul style="list-style-type: none"> ▪ Surcharging of 5.20 feet in MH-2831.

**TABLE 6.02-18
 100-YEAR RECURRENCE INTERVAL MANHOLE/PIPE SURCHARGE SUMMARY SOUTH BASIN**

Location	Description
65th Street	<ul style="list-style-type: none"> ▪ Surcharging of 6.46 feet in MH-2592. ▪ Pipe segment P-592 projected peak flow is 1.7 times full gravity capacity. ▪ Surcharging of 6.97 feet in MH-2594. ▪ Pipe segment P-591 projected peak flow is 1.6 times full gravity capacity. ▪ Surcharging of 7.69 feet in MH-2630. ▪ Pipe segment P-594 projected peak flow is 2.2 times full gravity capacity.
51st Avenue	<ul style="list-style-type: none"> ▪ Surcharging of 6.62 feet in MH-3080.
50th Avenue	<ul style="list-style-type: none"> ▪ Surcharging of 7.09 feet in MH-2831.

SECTION 7
ENGINEERING ANALYSIS: STORM SEWER

7.01 HYDROLOGIC ANALYSIS

A. Purpose of Evaluation

A watershed model was developed for the Forest Park Area and upstream and downstream areas. This model estimated peak discharges and stormwater runoff volumes from individual drainage subbasins under existing land use conditions. This data was used to size stormwater detention and conveyance facilities and estimate potential flood depths at critical watershed locations.

B. Methodology

For this project, hydrologic models were developed using the RUNOFF module of the computer model xp-swmm Version 2009. xp-swmm is a proprietary model based on the United States Environmental Protection Agency (USEPA)-developed Stormwater Management Model (SWMM). xp-swmm estimates peak stormwater discharges and volumes based on mathematical input parameters representing precipitation depth and time distribution, drainage area, land use, and time of concentration for each subbasin. Primary input parameters include the drainage area, runoff curve number (RCN), and time of concentration (T_c). The RCN considers land use and percentage of impervious area, soil type, and saturation conditions to impact the volume of stormwater runoff generated for a given rainfall depth. The T_c is the time it takes for stormwater to travel from the most hydrologically remote point in the watershed to the subbasin outlet. Parameters representing rainfall depth and distribution and watershed storage are also included in the model.

Based on user input coding, xp-swmm generates hydrographs for each subbasin, routes them through storage areas, and combines them at appropriate locations. The result is a rainfall-runoff model of the storm event of interest. For this project, hydrographs were generated for the 2-, 5-, 10-, 25-, 50- and 100-year storms under existing land use conditions. The SEWRPC rainfall amounts and distribution were analyzed for this project. A sensitivity analysis was performed in the original report to identify the storm duration resulting in the highest probable peak discharges at various watershed locations (typically referred to as the “critical duration”). Our analysis concluded that the critical storm duration creating the greatest peak discharges watershed-wide under existing land use conditions is a 2-hour storm. We have analyzed each of our alternatives for the 10-, 25- and 100-year storm events of 2-hour duration. In some cases the 25- and 100-year storm event was not run if the 10-year impacts were not significant.

C. Hydrologic Modeling Results

Table 7.01-1 includes summaries of peak discharges calculated by xp-swmm for each subbasin in the modeled watersheds for existing land use conditions for a 2-hour duration storm. Peak discharges for the May 20 to 23, 2004, storm are arrived at by using RCNs that are 25 percent higher than existing land use conditions to account for the substantial rainfall in the weeks leading up to the May 20 to 23, 2004, storm event as described in Section 2.

TABLE 7.01-1

STORM SEWER MODELING

Basin ID	Structure ID	Max Flow (cfs)						
		2-Yr	5-Yr	10-Yr	25-Yr	50-Yr	100-Yr	May 04
CM1	800	6.8	13.6	20.0	32.2	44.0	58.2	17.5
CM10	10215	45.6	67.3	84.9	115.1	141.9	172.2	50.3
CM11	13112	14.1	22.9	30.5	44.0	56.3	70.6	21.2
CM12	12921	32.3	52.3	69.4	99.6	127.2	159.3	50.2
CM13	12737	48.1	79.4	106.6	155.3	200.0	252.4	93.3
CM14	12350	25.6	40.1	52.3	73.8	93.1	115.4	41.1
CM15	7497	7.0	11.1	14.6	20.7	26.3	32.7	12.5
CM16	10224	5.2	8.5	11.3	16.2	20.7	26.0	9.2
CM17	11971	1.2	1.9	2.5	3.6	4.5	5.6	1.9
CM18	12146	5.5	8.9	11.8	17.0	21.8	27.3	9.5
CM19	6139	23.8	38.8	51.7	74.7	95.7	120.0	45.6
CM2	900	26.3	42.2	55.7	79.7	101.7	127.1	35.9
CM20	6089	6.0	9.8	13.0	18.8	24.1	30.2	11.6
CM21	6057	10.5	17.1	22.7	32.8	42.0	52.7	20.0
CM22	6046	5.3	8.6	11.4	16.5	21.1	26.4	10.1
CM23	6040	10.0	15.9	20.9	29.8	37.9	47.2	18.2
CM24	6028	1.1	1.9	2.5	3.6	4.6	5.7	2.2
CM3	15978	11.8	18.9	24.8	35.3	44.7	55.7	15.9
CM4	3161	16.4	24.4	30.9	42.2	52.1	63.4	16.6
CM5	3173	43.8	70.2	92.8	132.8	169.0	211.4	64.5
CM6	3183	20.8	33.3	44.0	62.9	80.0	99.9	30.2
CM7	3192	39.8	62.2	81.1	114.4	144.5	179.1	52.9
CM8	3206	19.1	31.2	41.6	60.2	77.2	97.2	27.6
CM9	3097	23.3	34.5	43.6	59.2	73.0	88.6	25.2
FPN1	5820	0.1	0.1	0.2	0.2	0.3	0.4	0.1
FPN10	5797	0.2	0.4	0.5	0.7	0.9	1.2	0.4
FPN11	5734	0.1	0.2	0.3	0.4	0.5	0.6	0.2
FPN12	5733	0.9	1.4	1.9	2.7	3.5	4.4	1.7
FPN13	5736	0.5	0.9	1.2	1.7	2.2	2.7	1.0
FPN14	5799	0.2	0.4	0.6	1.0	1.3	1.7	0.7
FPN15	5789	0.4	0.9	1.4	2.3	3.2	4.3	1.6
FPN16	5802	0.1	0.2	0.3	0.4	0.6	0.7	0.2
FPN17	5796	0.0	0.0	0.1	0.1	0.1	0.2	0.0
FPN18	17546	0.1	0.1	0.2	0.3	0.4	0.5	-
FPN19	5795	0.2	0.4	0.5	0.8	1.0	1.3	0.6
FPN2	5819	0.2	0.3	0.4	0.6	0.8	1.0	0.3
FPN20	5793	0.8	1.4	1.9	2.8	3.6	4.5	2.1
FPN21	17545	0.3	0.5	0.7	1.0	1.3	1.7	-
FPN22	5792	0.4	0.6	0.8	1.1	1.5	1.8	0.6
FPN23	5784	0.1	0.2	0.3	0.4	0.5	0.7	0.2
FPN24	5786	0.3	0.6	0.7	1.1	1.4	1.7	0.6
FPN25	5787	1.7	2.7	3.6	5.2	6.7	8.4	3.0

Basin ID	Structure ID	Max Flow (cfs)						
		2-Yr	5-Yr	10-Yr	25-Yr	50-Yr	100-Yr	May 04
FPN26	5785	0.8	1.2	1.6	2.3	3.0	3.8	1.4
FPN27	5781	0.5	1.2	1.7	2.8	3.9	5.2	1.8
FPN28	5737	0.3	0.5	0.7	1.1	1.4	1.9	0.7
FPN29	5740	1.4	2.2	3.0	4.3	5.6	7.1	2.7
FPN3	5816	0.5	0.9	1.1	1.6	2.1	2.6	0.9
FPN30	5739	1.6	2.5	3.4	4.9	6.3	7.8	2.8
FPN31	5741	0.5	0.8	1.1	1.6	2.0	2.5	0.9
FPN32	5742	1.2	2.0	2.6	3.8	4.9	6.1	2.2
FPN33	5743	0.3	0.4	0.5	0.6	0.7	0.8	0.2
FPN34	5748	0.1	0.2	0.3	0.4	0.5	0.6	0.2
FPN35	5747	0.4	0.6	0.8	1.1	1.4	1.8	0.7
FPN36	5746	0.3	0.4	0.4	0.6	0.7	0.8	0.2
FPN37	5771	1.4	2.4	3.3	4.9	6.4	8.2	2.8
FPN38	5772	0.3	0.7	1.0	1.6	2.2	3.0	1.1
FPN39	5769	2.0	3.3	4.5	6.5	8.4	10.7	3.7
FPN4	5817	0.2	0.3	0.4	0.5	0.7	0.9	0.3
FPN40	5767	0.8	1.3	1.6	2.3	2.9	3.6	1.1
FPN41	5766	1.3	2.1	2.7	3.9	4.9	6.1	2.0
FPN42	5764	0.7	1.0	1.3	1.8	2.3	2.8	0.9
FPN43	5763	0.8	1.2	1.5	2.1	2.6	3.3	1.0
FPN44	5762	1.0	1.5	2.0	2.8	3.5	4.3	1.4
FPN45	5760	0.7	1.2	1.6	2.4	3.1	4.0	1.3
FPN46	5759	0.2	0.3	0.4	0.7	0.9	1.1	0.4
FPN47	5758	0.4	0.7	0.9	1.3	1.7	2.2	0.7
FPN48	5756	1.1	1.8	2.4	3.5	4.6	5.8	1.9
FPN49	5752	0.0	0.0	0.0	0.1	0.1	0.1	0.0
FPN5	5803	0.2	0.3	0.3	0.4	0.5	0.6	0.2
FPN50	5755	0.2	0.4	0.5	0.7	1.0	1.2	0.4
FPN51	5619	0.2	0.2	0.3	0.4	0.4	0.5	0.1
FPN52	5618	0.3	0.5	0.7	1.0	1.3	1.7	0.6
FPN53	5613	0.5	0.9	1.1	1.6	2.1	2.6	0.9
FPN54	5615	1.7	2.8	3.8	5.4	6.9	8.7	3.3
FPN55	5621	0.7	1.1	1.4	2.0	2.6	3.2	1.2
FPN56	5620	0.2	0.2	0.3	0.5	0.6	0.7	0.3
FPN57	5657	0.4	0.7	1.0	1.5	2.0	2.5	0.8
FPN58	5659	0.9	1.5	1.9	2.8	3.6	4.5	1.8
FPN59	5660	1.6	2.8	3.7	5.5	7.1	9.1	3.1
FPN6	5805	0.9	1.4	1.9	2.8	3.5	4.5	1.6
FPN60	5655	0.3	0.5	0.7	1.0	1.3	1.7	0.5
FPN61	5654	1.7	3.0	4.1	6.2	8.1	10.4	3.5
FPN62	5652	0.9	1.5	2.0	3.0	3.9	5.0	1.7
FPN63	5656	0.2	0.4	0.5	0.8	1.0	1.3	0.4
FPN64	5650	2.6	4.7	6.5	9.8	12.9	16.6	6.6
FPN65	5648	1.1	1.9	2.7	4.1	5.4	6.9	2.3
FPN66	5651	0.2	0.3	0.5	0.7	0.9	1.2	0.4
FPN67	5626	2.1	3.6	4.9	7.4	9.7	12.4	4.4

Basin ID	Structure ID	Max Flow (cfs)						
		2-Yr	5-Yr	10-Yr	25-Yr	50-Yr	100-Yr	May 04
FPN68	5625	0.4	0.7	0.9	1.4	1.8	2.3	0.7
FPN69	5627	0.6	1.1	1.6	2.4	3.2	4.1	1.3
FPN7	5806	0.5	0.9	1.2	1.8	2.4	3.1	1.0
FPN70	5633	1.0	1.9	2.7	4.3	5.8	7.6	2.4
FPN71	5628	0.2	0.4	0.5	0.8	1.0	1.3	0.4
FPN72	5629	0.3	0.5	0.7	0.9	1.2	1.5	0.6
FPN73	5630	0.3	0.5	0.6	0.9	1.1	1.4	0.5
FPN74	5637	0.4	0.6	0.8	1.1	1.3	1.6	0.5
FPN75	5635	0.9	1.2	1.4	1.8	2.1	2.4	0.6
FPN76	5631	0.7	1.0	1.3	1.7	2.1	2.6	0.8
FPN77	5632	2.0	3.2	4.3	6.3	8.0	10.1	3.5
FPN78	5638	0.5	0.9	1.2	1.7	2.2	2.8	0.9
FPN79	5640	0.6	0.9	1.3	1.8	2.4	3.0	1.0
FPN8	5801	0.6	1.1	1.6	2.4	3.2	4.1	1.3
FPN80	3961	3.0	4.0	4.9	6.3	7.5	8.9	2.3
FPN81	3960	1.2	1.6	1.9	2.4	2.8	3.2	0.8
FPN82	8551	2.1	2.8	3.3	4.1	4.8	5.6	1.4
FPN83	8162	0.8	1.1	1.3	1.6	1.9	2.3	0.6
FPN84	5777	0.3	0.5	0.7	1.0	1.2	1.6	0.5
FPN85	5775	0.2	0.3	0.4	0.5	0.7	0.8	0.3
FPN86	5778	0.2	0.4	0.5	0.7	0.9	1.1	0.4
FPN87	5779	0.4	0.6	0.8	1.2	1.5	1.9	0.7
FPN9	5790	0.2	0.3	0.4	0.7	0.9	1.1	0.4
FPS1	6024	1.2	2.0	2.7	3.8	4.9	6.1	2.2
FPS10	5721	1.0	1.6	2.1	3.0	3.9	4.8	1.7
FPS11	5720	1.5	2.4	3.1	4.5	5.8	7.2	2.6
FPS12	5718	1.0	1.6	2.1	3.1	3.9	4.9	1.8
FPS13	5715	1.4	2.3	3.1	4.5	5.7	7.2	2.6
FPS14	5716	0.2	0.2	0.3	0.4	0.4	0.5	0.1
FPS15	5714	0.4	0.7	0.9	1.3	1.6	2.1	0.7
FPS16	5713	0.1	0.1	0.1	0.2	0.3	0.3	0.1
FPS17	5751	0.6	1.0	1.3	1.9	2.4	3.0	1.0
FPS18	5749	0.4	0.6	0.8	1.2	1.5	1.9	0.7
FPS19	5712	1.6	2.6	3.5	5.0	6.5	8.1	3.1
FPS2	6025	0.4	0.6	0.8	1.2	1.5	1.9	0.7
FPS20	5710	0.3	0.4	0.5	0.6	0.7	0.8	0.2
FPS21	5706	0.7	1.2	1.6	2.3	2.9	3.6	1.3
FPS22	5707	2.0	3.2	4.3	6.1	7.8	9.7	3.3
FPS23	5708	0.3	0.4	0.6	0.8	1.0	1.3	0.4
FPS24	5704	0.2	0.4	0.5	0.7	0.9	1.1	0.4
FPS25	5709	0.0	0.1	0.1	0.1	0.2	0.2	0.1
FPS26	5701	0.5	0.9	1.2	1.8	2.3	2.9	1.0
FPS27	5703	1.7	2.8	3.9	5.8	7.5	9.5	3.4
FPS28	5606	0.4	0.6	0.8	1.1	1.5	1.9	0.7
FPS29	9733	0.3	0.5	0.7	1.0	1.3	1.7	0.6
FPS3	6023	1.2	2.0	2.6	3.7	4.8	6.0	2.1

Basin ID	Structure ID	Max Flow (cfs)						
		2-Yr	5-Yr	10-Yr	25-Yr	50-Yr	100-Yr	May 04
FPS30	5609	1.5	2.6	3.5	5.2	6.8	8.7	3.3
FPS31	5608	1.5	2.5	3.3	4.8	6.2	7.8	2.8
FPS32	5611	0.2	0.3	0.4	0.6	0.8	1.0	0.3
FPS33	5610	0.7	1.2	1.6	2.3	2.9	3.6	1.3
FPS34	5671	0.3	0.5	0.7	1.0	1.3	1.6	0.6
FPS35	5672	1.3	2.1	2.8	4.1	5.3	6.6	2.6
FPS36	5670	0.3	0.5	0.7	0.9	1.2	1.5	0.5
FPS37	5678	1.3	2.1	2.7	3.9	5.0	6.3	2.3
FPS38	5677	0.8	1.4	2.0	3.1	4.1	5.3	1.8
FPS39	5683	0.3	0.5	0.8	1.1	1.5	1.9	0.6
FPS4	5722	0.3	0.5	0.6	0.9	1.1	1.4	0.5
FPS40	5682	0.9	1.5	2.0	3.0	4.0	5.1	1.7
FPS41	5681	0.9	1.4	1.8	2.4	3.0	3.7	1.2
FPS42	5679	0.5	0.8	1.0	1.3	1.6	2.0	0.6
FPS43	5675	0.2	0.3	0.4	0.6	0.8	1.1	0.4
FPS44	5676	0.3	0.5	0.7	1.0	1.3	1.6	0.6
FPS45	5673	2.4	4.0	5.3	7.7	10.0	12.6	4.6
FPS46	5666	0.2	0.3	0.3	0.4	0.5	0.6	0.2
FPS47	5665	0.5	0.8	1.1	1.6	2.1	2.6	1.0
FPS48	5668	0.4	0.6	0.8	1.2	1.5	1.9	0.7
FPS49	5663	1.6	2.6	3.5	5.0	6.5	8.2	3.0
FPS5	5725	0.2	0.3	0.4	0.6	0.7	0.9	0.3
FPS50	5662	0.6	1.0	1.3	1.9	2.5	3.1	1.2
FPS6	5726	0.2	0.2	0.3	0.4	0.5	0.6	0.2
FPS7	5727	0.3	0.5	0.7	1.0	1.2	1.5	0.5
FPS8	5728	0.2	0.3	0.4	0.6	0.7	0.9	0.3
FPS9	5719	0.2	0.3	0.3	0.4	0.5	0.6	0.1
FPW1	11959	29.7	46.8	61.2	86.5	109.3	135.8	49.9
FPW10	7566	6.1	10.2	13.8	20.2	26.2	33.2	13.5
FPW11	KEN_COMMON	7.3	11.2	14.6	20.4	25.6	31.7	10.1
FPW12	8161	27.7	44.1	57.8	82.0	103.9	129.1	43.9
FPW13	11358	6.4	10.8	14.6	21.6	28.1	35.7	14.9
FPW2	11763	7.0	10.9	14.3	20.1	25.3	31.4	10.3
FPW3	16964	8.1	11.6	14.4	19.2	23.4	28.1	9.5
FPW4	11553	6.7	10.8	14.3	20.5	26.1	32.7	11.9
FPW5	10239	7.4	11.7	15.3	21.6	27.4	34.0	12.3
FPW6	9727	9.1	16.2	22.6	34.4	45.5	58.7	26.4
FPW7	OLD ELM	8.0	11.3	13.9	18.4	22.2	26.5	6.9
FPW8	NASH	29.5	50.3	68.7	102.0	133.0	169.5	73.4
FPW9	7637	7.4	12.6	17.1	25.2	32.8	41.6	17.0
PC1	13463	12.1	20.3	27.3	40.0	51.7	65.4	19.7
PC10	7388	25.8	40.4	52.7	74.1	93.5	115.7	44.4
PC11	12182	21.5	33.4	43.5	61.1	77.0	95.3	36.1
PC12	12373	3.0	4.5	5.7	7.7	9.6	11.6	3.6
PC13	8070	5.5	8.3	10.6	14.6	18.1	22.2	7.7
PC14	8064	4.6	7.1	9.2	12.9	16.2	20.0	6.8

Basin ID	Structure ID	Max Flow (cfs)						
		2-Yr	5-Yr	10-Yr	25-Yr	50-Yr	100-Yr	May 04
PC15	8094	7.5	11.8	15.5	21.9	27.7	34.4	11.0
PC16	8353	16.6	25.9	33.7	47.5	59.9	74.2	30.5
PC17	8378	31.8	50.9	67.2	96.1	122.2	152.6	53.5
PC18	8404	13.4	23.5	32.6	49.2	64.7	83.0	29.5
PC19	1-HILLSIDE	221.1	339.9	440.1	614.4	771.4	951.7	364.7
PC2	7731	27.3	41.9	54.1	75.1	94.1	115.9	36.5
PC20	15295	8.9	15.4	21.1	31.5	41.1	52.4	19.5
PC3	7725	93.4	131.9	162.6	214.3	259.6	310.3	85.4
PC4	8035	40.7	67.4	90.6	132.0	170.3	215.0	68.3
PC5	14412	4.2	8.6	12.8	20.9	28.7	38.1	11.3
PC6	10862	23.1	37.7	50.2	72.5	92.9	116.6	35.7
PC7	11081	30.3	45.2	57.4	78.4	97.0	118.2	33.0
PC8	11484	46.5	69.3	88.1	120.5	149.2	182.0	58.9
PC9	9763	37.7	57.8	74.6	103.9	130.0	160.2	61.3
SM1	4655	2.2	4.3	6.4	10.3	14.1	18.6	5.7
SM10	10257	14.4	24.2	32.8	48.3	62.6	79.4	24.5
SM11	2902	4.1	7.0	9.6	14.3	18.6	23.7	7.0
SM12	16427	42.7	74.8	103.4	155.8	204.8	262.7	67.7
SM13	16517	5.9	10.4	14.3	21.4	28.1	36.0	10.2
SM14	2466	1.3	2.0	2.6	3.8	4.9	6.2	1.8
SM15	2799	13.3	21.9	29.4	42.8	55.1	69.5	19.0
SM16	3320	13.6	25.8	37.1	58.3	78.4	102.8	28.9
SM17	4160	4.0	7.3	10.3	15.9	21.2	27.5	7.1
SM18	10300	11.2	20.8	29.6	45.8	61.2	79.7	23.6
SM19	4538	16.2	26.5	35.2	50.8	64.8	81.0	23.4
SM2	4696	3.2	6.3	9.2	14.8	20.1	26.6	8.0
SM20	10361	27.1	43.1	56.7	80.8	102.7	128.0	49.9
SM21	371	16.6	22.1	26.3	33.3	39.3	45.9	12.2
SM22	10362	11.6	18.7	24.8	35.6	45.4	56.9	17.3
SM23	4239	80.6	137.5	187.6	278.2	362.5	461.4	165.0
SM24	GRAYSTONE	41.0	62.9	81.4	113.5	142.2	175.4	68.2
SM25	4979	29.3	50.7	69.7	104.3	136.6	174.9	84.4
SM26	4466	21.6	35.7	47.8	69.4	89.2	112.6	46.0
SM27	15517	70.8	70.8	70.8	70.8	70.8	70.8	70.8
SM28	2-GANGLER	327.2	518.7	683.1	972.3	1235.6	1540.7	610.7
SM29	10001	6.7	10.9	14.5	21.0	26.9	33.7	11.7
SM3	16048	5.1	8.8	12.0	17.7	23.1	29.4	8.8
SM30	5431	29.5	49.1	66.2	96.7	124.9	158.0	64.9
SM31	5473	11.9	19.7	26.4	38.4	49.3	62.0	23.1
SM32	5491	20.1	33.7	45.4	66.5	85.9	108.8	39.3
SM33	5548	2.4	4.2	5.7	8.4	11.0	14.0	4.8
SM34	5554	12.7	21.4	29.1	42.8	55.6	70.6	25.4
SM35	9-BIBLE CHURCH	9.4	14.1	17.9	24.4	30.1	36.7	12.3
SM36	5698	3.9	6.3	8.4	12.0	15.4	19.2	6.5
SM4	16032	7.2	13.2	18.6	28.6	38.0	49.3	14.7

Basin ID	Structure ID	Max Flow (cfs)						
		2-Yr	5-Yr	10-Yr	25-Yr	50-Yr	100-Yr	May 04
SM5	5368	2.5	5.4	8.2	13.8	19.3	26.0	8.0
SM6	2941	1.7	3.6	5.5	9.2	12.8	17.2	5.7
SM7	4	15.2	29.2	42.2	66.3	89.5	117.3	37.2
SM8	3	19.3	32.7	44.6	66.0	85.9	109.3	33.6
SM9	2990	6.9	11.8	16.1	23.9	31.1	39.7	11.6

¹ In the May 2004 calibration model, Basins FPM 20 and 21 are combined at Structure ID 5793 and Basins FPM 17 and 19 are combined at Structure ID 5795. This is done to mimic the existence of only one inlet on each side of 46th Avenue between 60th and 61st Streets during the May 2004 storm event. Subsequent model runs have two inlets on each side of the street.

7.02 HYDRAULIC ANALYSIS

A. Methodology

The Extended Transport (EXTRAN) module of the xp-swmm computer model was used to calculate the hydraulic capacity of the existing storm sewer system under existing conditions. Figure 7.02-1 shows a schematic of the storm sewer network as modeled. EXTRAN is a dynamic flow routing model that routes inflow hydrographs through an open channel and/or closed conduit system, computing the time history of flows and heads throughout the system. Input to EXTRAN includes the following:

1. The physical geometry of the storm sewer system, including storm sewer sizes and shapes, ground and invert elevations, and storm sewer connectivity information. For this project, physical information regarding the storm sewer system was obtained from the City’s storm sewer GIS layer along with field survey information collected by the City.
2. Data regarding special hydraulic structures in the system including weirs, orifices, and storage junctions.
3. Roughness coefficients for existing and proposed conduits.
4. Inflow hydrographs at critical nodes in the system. For this project, hydrographs were computed using the xp-swmm RUNOFF module, as described in Section 7.01B.
5. Boundary conditions defining starting water surface elevations and other inlet and outlet conditions.

Critical components of this modeling effort are the “boundary conditions” used at the pipe discharge at Lake Michigan and the grease interceptor discharge at Pike Creek. “Boundary condition” means the assumed elevation of the water surface at the discharge point of the storm sewer or open channel being modeled.

For this project, Tables 7.02-1 and 7.02-2 show the boundary conditions for the Pike Creek and Lake Michigan outfalls, respectively. Section 2 describes the origin of this data.

The Pike Creek 100-year boundary condition of 598.92 is the elevation generated during the 2-hour 10-year duration storm event at the Pike Creek outfall. The 25-year and 50-year boundary conditions are generated by prorating between the 10-year free outfall condition and the 598.92 elevation.

The 10-Year Stillwater Elevation of Lake Michigan published in the *Flood Insurance Study, City of Kenosha, Wisconsin, Kenosha County*, FEMA, December 5, 1996, is 583.10 (NGVD29). However, information provided by the City in a December 14, 2009, e-mail indicates that the average water surface elevation of Lake Michigan at Kenosha is approximately 578.2 (NGVD29) with average high and low water surface elevations of approximately 580.2 (NGVD29) and 577.20 (NGVD29), respectively. Given this data, the

City indicated that the appropriate Lake Michigan 100-year boundary condition for modeling purposes is 580.00. The 25- and 50-year boundary conditions are generated by prorating between the 10-year boundary condition (which is the maximum lake level (high end of the range) of Lake Michigan (according to the City) and the 580.00 elevation.

Return Frequency	Elevation (ft)
May 2004 WSEL	Free Outfall
1-Year	Free Outfall
2-Year	Free Outfall
5-Year	Free Outfall
10-Year	Free Outfall-596.94
25-Year	597.27
50-Year	597.82
100-Year	598.92

Table 7.02-1 Boundary Conditions at Pike Creek Outfall (NGVD 29 Datum)

Return Frequency	Elevation (ft)
May 2004 WSEL	578.93
1-Year	579.42
2-Year	579.42
5-Year	579.42
10-Year	579.42
25-Year	579.52
50-Year	579.68
100-Year	580.00

Table 7.02-2 Boundary Conditions at Lake Michigan Outfalls (NGVD 29 Datum)


6. Stage-storage-outflow data for impoundments in the watershed, including detention at the Gangler, Graystone, Hillside, Kenosha Bible Church, Kenosha Commons, Lincoln Park, Nash Park, and Old Elm sites.

Output information from the EXTRAN model includes the following:

1. Time histories of flows and depths through individual storm sewer facility reaches for various storm events.
2. Estimates of cumulative stormwater volumes overflowing the system at various locations for extreme storm events.

B. Model Calibration

Calibration of the model to reproduce the elevations and flooding volumes that were reported during the May 2004 storm event was performed to compare modeled results with observed conditions. Figure 7.02-2 shows the locations of the high water depths provided by the City for the May 2004 storm event as well as the modeled flood extents during the May 2004 storm event. The model was calibrated to the elevations surveyed as the high water mark at Survey Point 117 (46th Avenue between 50th and 61st Street), Survey Point 118 (46th Avenue between 50th and 61st Street), Survey Point 119 (northeast corner of the 49th Avenue/61st Street intersection), and Survey Point 120 (50th Avenue between 65th Street and 67th Street). The surveyed depth of water is 12 inches, 0 inches, 14 inches, and 12 inches, respectively. The model shows that during the May 20 to 23, 2004, storm event the



**MAY 20-23, 2004 STORM EVENT
FLOOD EXTENTS**

**FOREST PARK AREA STORM AND SANITARY MANAGEMENT PLAN
CITY OF KENOSHA
KENOSHA COUNTY, WISCONSIN**



**FIGURE 7.02-2
1540.001**

S:\MAD\1500-1599\1540\001\Data\GIS Data\Figures\Report Figures\Storm Analysis\Figure 7.02-2 May 2004 Storm Event Map 11x17.mxd

corresponding depth of water at these locations is approximately 11.8 inches, 0.70 inches, 17.4 inches, and 7.8 inches, respectively. The model is thus within 0.2 inches, 0.70 inches, 3.4 inches, and 4.2 inches of the City’s measured elevations for an average of within 0.4 inches.

Given the uncertainty in the accuracy of these elevations/depths because they were based on memory of an event that occurred approximately six years ago, we believe based on these results, the model provides a reasonable representation of stormwater storage and conveyance in the modeled watershed during the May 20 to 23, 2004 storm event.

Modifications made to the model to arrive at this calibration include the following:

1. Use of Neenah inlet grate curves to simulate one-dimensional (1D) and two-dimensional (2D) inlet capture. All inlet grates were modeled with a 20 percent clogging factor.
2. Manholes with open grate lids in 2004 were modeled with 2D inlet capture meaning that flows entering them are restricted in accordance with Neenah inlet grate curves. There were six sealed lids in 2004 and the remaining manholes had open grate lids. The open grate lids were not provided with a clogging factor.
3. Use of a 1D and 2D 30 percent clogging factor at the following nodes (inlets): 5701, 5703, 5608, 5609, 5606, and 9733.
4. Use of a 2D 30 percent clogging factor at the following nodes (manholes): 5702, 5607, 9736, and 5768.
5. Use of a 1D and 2D 35 percent clogging factor at the following nodes (inlets): 5767, 5766, 5769, 5772, and 5771.
6. Use of a 2D land use that mimics houses in areas of flooding with a Manning’s “n” of 5 and all other surfaces with a Manning’s “n” of 0.024. Flows in the 2D model thus are basically forced around houses for conveyance by the Manning’s “n” differential.
7. Increase of pervious area curve numbers by 25 percent to account for the substantial rainfall in the weeks leading up to the May 20 to 23, 2004 storm event. The 25 percent increase in pervious area curve numbers increase the composite pervious area curve number from 69 (Antecedent Moisture Condition II) up to 86. This closely approximates Antecedent Moisture Condition III.
8. Insertion of standard loss factors and “n” values in the base model and supplementing of these with increased loss factors and “n” value increases to account for comments and defects reported in the storm sewer televising reports.
9. Use of a starting water surface elevation at the Lake Michigan outfalls recorded by NOAA in Milwaukee as the lake water surface elevation at 7 P.M. on May 20, 2004.

C. Design-Storm Evaluation

Modeling of existing conditions shows there are numerous areas with undersized stormwater conveyance facilities frequently exceeding their capacities and flood adjacent lands and streets. Table 7.02-3 lists the design capacity and physical characteristics of modeled links in the stormwater conveyance system.

Modeling provided the following observations:

1. Estimated Pipe Capacity in Limits of Detailed Study Area: Figure 7.02-3 shows the existing pipe capacity of each modeled pipe within the limits of the detailed study area. This analysis was performed assuming there is adequate inlet capacity for the various storm events to force a pipe control situation. This analysis reflects the true capacity of the pipe should there be adequate inlet capacity for the particular storm event or should the City provide additional inlets to match the design storm capacity of the pipe. The designated pipe capacity on this figure is based on model output that shows which storm event the upstream end of each pipe segment begins to surcharge to or above the ground surface.

As shown in Figure 7.02-3, there are several conclusions that can be made as follows:

- a. Forest Park North: There are significant storm sewer conveyance bottlenecks downstream of the Forest Park North area including the 42nd Avenue/59th Street and the Pershing Boulevard/60th Street area, as evidenced by the 2- and 5-year pipe capacities in the area. These bottleneck areas are a major cause of flooding in the Forest Park North Area.
- b. Forest Park South: There are numerous significant storm sewer conveyance bottlenecks downstream of the Forest Park South area including the 50th Avenue/67th Street area with a 5-year capacity and along 67th Place where there is a 2-year capacity. These bottleneck areas are a major cause of flooding in the Forest Park South area.
- c. There are numerous pipes in the modeled system that are listed between 10- and 100-year pipe capacity. One drawback to an analysis of this type is that the analysis assumes unlimited inlet capacity, which means that unless a matching inlet capacity exists in the watershed, the listed capacity will not be realized. For example, it is likely that even if a pipe had a 100-year potential capacity, it may never be realized because the watershed probably has only between a 2- to 10-year inlet capacity.

It is also important to realize that higher pipe capacities (10- to 100-year) shown on the figure are many times only at that capacity because upstream surface ponding attenuates flows to downstream conduits and results in a lower hydraulic grade line (HGL). Should a relief storm sewer be provided to relieve the upstream flooding, the particular storm sewer capacity would go down because of the increased flow.

It is also important to note that any change in either conveyance (pipe size change) or storage (addition of detention) will immediately change Figure 7.02-3 in the area of the improvement.

2. Existing Conditions Flood Extents Maps: Figures 7.02-4 through 7.02-9 show the existing conditions flood extents maps. These models were run with a 20 percent clogging factor to mimic what might be an expected level of blockage during a typical storm event.

3. Automated Inlet Capacity Estimation: An automated inlet capacity estimation was completed utilizing xp-swmm 2D. Both the Forest Park North and South watersheds have less than a 10-year inlet capacity. Table 7.02-4 shows the existing and additional numbers of inlets necessary in the watersheds to achieve a 10-year inlet capacity.

	Existing Inlets	Rebuild Existing Inlets*	New Inlets
Forest Park North	84	33	50
Forest Park South	48	21	32
Total	132	54	82

*Only rebuild existing inlets where new inlets are needed.

Table 7.02-4 Automated Inlet Capacity Estimation

The locations of these inlets are shown in Figures 9.03-3 and 9.07-1. This analysis was completed following WisDOT Facilities Development Manual (FDM) Procedure 13-25-30 Inlet Clogging Factors (35 percent clogging factor at sump inlets and 45 percent clogging factor at on-grade inlets) with no greater than 3 inches of water depth. In locations where multiple inlets are shown, these inlets could be replaced with a single high capacity inlet during design. Alternatives 1 through 7 described in Section 9 utilize this analysis as appropriate for the Alternative.



4. Spreadsheet Inlet and Inlet Lead Capacity Estimation: As part of Amendment No. 2 to this project, a spreadsheet inlet and inlet lead capacity estimation was completed for the Forest Park North and South Areas to convey the 10-year, 2-hour design storm event. This analysis was completed using the following assumptions:
 - a. Analysis is under existing land use conditions.
 - b. Analysis is independent of the mainline storm sewer capacity such that inlet leads are sized for full flow capacity without tailwater.
 - c. Existing non-City standard inlets and grates are upgraded to City standard inlets and grates (R3067 Casting, Type V Grate).
 - d. Analysis is completed following WisDOT Facilities Development Manual (FDM) Procedure 13-25-30 Inlet Clogging Factors (35 percent clogging factor at sump inlets and 45 percent clogging factor at on-grade inlets) with no greater than 3 inches of water depth at a particular inlet.
 - e. Classification of an inlet as a Sag or On-Grade inlet was completed using the best available information for this planning-level study. We anticipate the inlet analysis will be rerun in specific areas during design to capture any changes to the sag/on-grade classification after field survey is complete.

Legend

- Watershed Divide
- Manhole
- Inlet
- Storm Sewer
- ▭ Storm Sewer Study Limits

Depth (ft)

- 0 - 0.16
- 0.16 - 0.25
- 0.25 - 0.5
- 0.5 - 0.75
- 0.75 - 1.5
- 1.5 - 2
- 2 - 2.5
- 2.5 - 3
- 3 - 3.5
- 3.5 - 4.5
- 4.5 - 5.08




**2-YEAR 2-HOUR DURATION
FLOOD EXTENTS**

**FOREST PARK AREA STORM AND SANITARY MANAGEMENT PLAN
CITY OF KENOSHA
KENOSHA COUNTY, WISCONSIN**



**FIGURE 7.02-4
1540.001**




**5-YEAR 2-HOUR DURATION
FLOOD EXTENTS**

**FOREST PARK AREA STORM AND SANITARY MANAGEMENT PLAN
CITY OF KENOSHA
KENOSHA COUNTY, WISCONSIN**



**FIGURE 7.02-5
1540.001**




**10-YEAR 2-HOUR DURATION
FLOOD EXTENTS**

**FOREST PARK AREA STORM AND SANITARY MANAGEMENT PLAN
CITY OF KENOSHA
KENOSHA COUNTY, WISCONSIN**



**FIGURE 7.02-6
1540.001**




**25-YEAR 2-HOUR DURATION
FLOOD EXTENTS**

**FOREST PARK AREA STORM AND SANITARY MANAGEMENT PLAN
CITY OF KENOSHA
KENOSHA COUNTY, WISCONSIN**



**FIGURE 7.02-7
1540.001**



Legend

- Watershed Divide
- Manhole
- Inlet
- Storm Sewer
- Storm Sewer Study Limits

Depth (ft)


- 0 - 0.16
- 0.16 - 0.25
- 0.25 - 0.5
- 0.5 - 0.75
- 0.75 - 1.5
- 1.5 - 2
- 2 - 2.5
- 2.5 - 3
- 3 - 3.5
- 3.5 - 4.5
- 4.5 - 5.08

**50-YEAR 2-HOUR DURATION
FLOOD EXTENTS**

**FOREST PARK AREA STORM AND SANITARY MANAGEMENT PLAN
CITY OF KENOSHA
KENOSHA COUNTY, WISCONSIN**



**FIGURE 7.02-8
1540.001**



**100-YEAR 2-HOUR DURATION
FLOOD EXTENTS**

**FOREST PARK AREA STORM AND SANITARY MANAGEMENT PLAN
CITY OF KENOSHA
KENOSHA COUNTY, WISCONSIN**



**FIGURE 7.02-9
1540.001**

This analysis also shows that both the Forest Park North and South watersheds have less than a 10-year inlet capacity. Table 7.02-5 shows the existing and additional numbers of inlets necessary in the watersheds to achieve a 10-year inlet capacity. Table 7.02-6 shows the storm sewer inlet lead upsizing necessary to achieve a 10-year inlet lead capacity. Figures 7.02-10 and 7.02-11 show the locations of the required inlet and inlet lead improvements to convey the 10-year design storm. The calculations supporting these two figures are located in Appendices R and S.

	Existing Inlets	Existing City Standard Inlets	Rebuild Existing Inlets	Existing R-3067V Casting-Needs Further Investigation	New Inlets
Forest Park North	89	13	73	1	53
Forest Park South	53	7	43	13	33
Total	142	20	116	14	86

Table 7.02-5 Spreadsheet Inlet Capacity Estimation

	12-Inch Inlet Lead (ft)	15-Inch Inlet Lead (ft)	18-Inch Inlet Lead (ft)	Total Length (ft)
Forest Park North	1,334	210	43	1,587
Forest Park South	677	261	20	953
Total Length (ft)	2,011	471	63	2540

Table 7.02-6 Required Inlet Lead Upsizing

The placement of these inlets is a planning-level deliverable. We recommend that the final placement of the inlets be determined during design. Please note the attached figures show inlets that have R-3067V castings that need further investigation. It appears these inlets have been rebuilt with the new casting. However, it is unclear if the box structure was rebuilt with the City 2-foot by 3-foot box standard. For cost estimating purposes in this report, it is assumed that these inlets will need to be rebuilt with a 2-foot by 3-foot box.

The inlet and inlet lead upgrades described above were incorporated into the xp-swmm model. The model was run for the 10-, 25-, and 100-year design storm events using appropriate tailwater conditions at the Pike Creek and Lake Michigan outfalls. The resultant flood extent maps are included as Figures 7.02-12, 7.02-13, and 7.02-14 for the Forest Park North Area and Figures 7.02-15, 7.02-16, and 7.02-17 for the Forest Park South Area. These can be compared with the existing conditions flood extents maps included as Figures 7.02-18, 7.02-19, and 7.02-20 for the Forest Park North Area and Figures 7.02-21, 7.02-22, and 7.02-23 for the Forest Park South Area. A comparison shows that certain locations benefit from additional inlets and upsized leads and others do not, dependent on whether there is adequate downstream mainline capacity. Appendix L and M include the storm sewer mainline 10-year storm event profiles under existing conditions for the Forest Park North and South Areas, respectively.

The opinion of probable construction cost for the inlet and inlet lead upgrades is shown in Table 7.02-7 including design and construction contingencies. The detailed opinions of probable cost are included in Appendix G.

	Opinion of Probable Construction Cost
Forest Park North	\$561,600
Forest Park South	\$354,900

Table 7.02-7 Opinion of Probable Construction Cost-Inlet and Inlet Lead Improvements

- 60th Street/52nd Avenue Intersection Modeling: Figures 7.02-4 through 7.02-9 show the original existing conditions flood extent maps for the 2-, 5-, 10-, 25-, 50-, and 100-year storm events. The original existing conditions flood extent maps utilized the xp-swmm modeling framework upstream of this intersection as included in a previous consultant’s xp-swmm mainline model and as outlined in our Agreement with the City. During completion of the Amendment No. 2 services, it was determined the mainline model needed to be expanded to better represent the storm sewer system and localized flooding in this area. For this reason, the xp-swmm model was expanded to add an existing storm sewer from the 58th Street/52nd Avenue intersection to the 58th Street/51st Avenue intersection. The 58th Street/51st Avenue intersection is located at a lower elevation than the 60th Street/52nd Avenue intersection and, thus, will begin flooding prior to the 60th Street/52nd Avenue intersection.

The xp-swmm model was rerun to create new existing conditions flood extent maps for the 10-, 25-, and 100-year storm events (Figures 7.02-18 through 7.02-20). As shown in Figure 7.02-18 (10-year storm event), the 58th Street/51st Avenue intersection floods and the 60th Street/52nd Avenue intersection does not flood because the 58th Street/51st Avenue intersection is at a lower elevation. It is our understanding that this is more in-line with the City’s field observations in this area. Figure 7.02-19 (25-year storm event), likewise, shows less depth of flooding in the 60th Street/52nd Avenue intersection than the 58th Street/51st Avenue intersection when compared to the original flood extent maps (Figures 7.02-7) for the same reason. During the 100-year storm event (Figure 7.02-20), however, the effect is less pronounced as the flooding becomes interconnected between the two intersections. From a freeboard standpoint at 5150 52nd Avenue, there is N/A, 0.64 feet, and -0.66 feet of freeboard for the 10-, 50-, and 100-year storm events, respectively. It is our understanding that the City will provide documentation of the results of conversations with property owners surrounding the 60th Street/52nd Avenue intersection regarding the history of flooding at the intersection.

TABLE 7.02-3

STORM SYSTEM CHARACTERISTICS

Name	Diameter (ft)	Shape	Roughness	Conduit Slope (%)	Length (ft)	Design Flow (cfs)
P-1	2.50	Circular	0.014	0.37	32	23
P-10.1	1.50	Circular	0.014	1.54	88	12
P-100	4.00	Circular	0.014	2.53	9	212
P-1000	5.17	Special	0.014	2.21	35	660
P-10001.1	4.00	Circular	0.014	1.13	353	142
P-1001	1.00	Trapezoidal	0.060	0.12	343	46
P-1002	1.00	Trapezoidal	0.150	0.76	644	45
P-1003	0.50	Trapezoidal	0.011	1.25	349	30
P-10042	2.50	Circular	0.014	0.31	116	21
P-10196	6.50	Circular	0.014	0.30	236	269
P-10197	6.50	Circular	0.014	0.33	331	279
P-10199.1	4.50	Circular	0.014	1.09	179	190
P-10215	8.00	Circular	0.014	0.36	56	506
P-10221	4.00	Circular	0.014	14.51	38	508
P-10222	4.00	Circular	0.014	0.45	146	89
P-10224	3.50	Circular	0.014	0.12	188	33
P-10226	3.50	Circular	0.014	0.12	17	32
P-10229	4.00	Circular	0.014	0.57	194	102
P-10231.1	1.75	Circular	0.014	1.89	86	20
P-10232.1	4.00	Circular	0.014	0.81	258	120
P-10233.1	4.00	Circular	0.014	1.96	42	187
P-10235	3.00	Circular	0.014	0.76	53	54
P-10239	3.00	Circular	0.014	0.90	537	59
P-10240	2.50	Circular	0.014	0.56	404	29
P-10241	3.00	Circular	0.014	0.40	166	39
P-10257	7.00	Circular	0.014	0.29	118	318
P-10259	7.57	Rectangular	0.014	0.06	70	320
P-10260	7.00	Circular	0.014	0.04	256	111
P-10298	6.50	Circular	0.014	0.33	331	280
P-10299.1	6.50	Circular	0.014	0.37	289	296
P-10300.1	6.50	Circular	0.014	0.35	280	290
P-10301	6.50	Circular	0.014	0.36	290	293
P-10326	6.50	Circular	0.014	0.71	149	410
P-10347	3.50	Circular	0.014	0.32	76	53
P-10357	6.50	Circular	0.014	0.24	166	239
P-10361.1	4.00	Circular	0.014	0.49	420	93
P-10362.1	6.50	Circular	0.014	0.36	473	290
P-10366	5.00	Circular	0.014	7.30	27	653
P-10464.1	4.50	Circular	0.014	0.63	333	145
P-10549.1	4.50	Circular	0.014	0.55	56	135
P-10554	8.00	Circular	0.014	0.32	207	482

Name	Diameter (ft)	Shape	Roughness	Conduit Slope (%)	Length (ft)	Design Flow (cfs)
P-10673	4.50	Circular	0.014	0.41	554	117
P-10862.1	6.50	Circular	0.014	0.31	259	271
P-1100	0.00	Trapezoidal	0.011	16.52	21	18,822
P-11073.1	6.50	Circular	0.014	-0.12	61	165
P-11074.1	6.50	Circular	0.014	0.46	221	331
P-11081.1	6.50	Circular	0.014	0.27	289	255
P-111	1.50	Circular	0.014	0.16	82	4
P-11264	6.50	Circular	0.014	0.39	284	304
P-11271	6.50	Circular	0.014	0.03	160	86
P-11272.1	6.50	Circular	0.014	0.59	134	373
P-11352	3.00	Circular	0.014	0.39	157	39
P-11358	3.00	Circular	0.014	0.98	47	61
P-11359	3.00	Circular	0.014	1.01	285	62
P-11361	3.00	Circular	0.014	1.41	315	74
P-11414.1	4.50	Circular	0.014	0.73	331	156
P-11482	6.00	Circular	0.014	0.20	35	175
P-11484.1	6.00	Circular	0.014	0.79	169	350
P-11553	3.50	Circular	0.014	0.79	103	83
P-11748	1.50	Circular	0.014	5.10	279	22
P-11763.1	1.50	Circular	0.014	1.99	309	14
P-11959.1	4.00	Circular	0.014	0.67	255	98
P-11962	4.00	Circular	0.014	0.41	274	85
P-11971	3.00	Circular	0.014	1.05	533	64
P-12	1.50	Circular	0.014	0.00	59	0
P-12146	4.00	Circular	0.014	0.59	29	102
P-12146N	4.00	Circular	0.014	1.35	32	141
P-12155	3.50	Circular	0.014	3.31	67	170
P-12160	4.00	Circular	0.014	0.80	98	118
P-12182	6.00	Circular	0.014	0.26	256	200
P-12189	6.00	Circular	0.014	0.09	173	120
P-12190	6.00	Circular	0.014	0.32	170	222
P-12349	4.00	Circular	0.014	0.18	181	56
P-12350	7.00	Circular	0.014	0.33	291	339
P-12373	6.00	Circular	0.014	0.16	205	155
P-12376	4.00	Circular	0.014	0.41	180	85
P-12379	6.00	Circular	0.014	0.61	173	307
P-12541	7.00	Circular	0.014	0.33	424	343
P-12547.1	7.00	Circular	0.014	0.12	66	207
P-12552.1	7.00	Circular	0.014	0.34	280	344
P-12601.1	6.50	Circular	0.014	0.46	170	330
P-12737.1	7.00	Circular	0.014	0.36	275	358
P-12745.1	7.00	Circular	0.014	0.30	277	323
P-12921	8.00	Circular	0.014	0.29	185	458
P-12923	8.00	Circular	0.014	0.33	146	486
P-12928	8.00	Circular	0.014	0.30	365	461

Name	Diameter (ft)	Shape	Roughness	Conduit Slope (%)	Length (ft)	Design Flow (cfs)
P-13112	8.00	Circular	0.014	0.34	304	493
P-13117	8.00	Circular	0.014	0.31	159	475
P-13120	8.00	Circular	0.014	0.32	161	477
P-13124	8.00	Circular	0.014	0.31	387	474
P-13127	8.00	Circular	0.014	0.34	114	495
P-13129	8.00	Circular	0.014	0.33	95	484
P-13131	8.00	Circular	0.014	0.32	112	480
P-13135	8.00	Circular	0.014	0.32	157	478
P-13141	8.00	Circular	0.014	0.31	201	474
P-13295	8.00	Circular	0.014	0.30	280	467
P-13299	8.00	Circular	0.014	0.33	126	483
P-13463	6.50	Circular	0.014	0.71	81	409
P-13464	6.50	Circular	0.014	0.38	217	299
P-1400 ¹	20.00	Natural	0.014	3.00	28	342,875
P-14302	7.00	Circular	0.014	0.10	390	185
P-14386	2.50	Circular	0.014	0.18	291	16
P-14412.1	6.50	Circular	0.014	0.41	326	312
P-1486	6.50	Circular	0.014	0.36	300	292
P-1486001	6.50	Circular	0.014	0.86	52	452
P-1487	6.50	Circular	0.014	0.21	155	221
P-14911	4.00	Circular	0.014	0.63	24	106
P-14912	4.00	Circular	0.014	0.58	235	102
P-15280	4.50	Circular	0.014	0.42	463	118
P-15284	6.50	Circular	0.014	0.31	198	270
P-15293	6.00	Circular	0.014	0.79	95	349
P-15294	6.00	Circular	0.014	0.13	200	142
P-15295	6.00	Circular	0.014	0.14	231	146
P-15306.1	4.50	Circular	0.014	0.26	174	93
P-15312.1	6.50	Circular	0.014	0.18	102	205
P-15316001	4.50	Circular	0.014	0.82	421	165
P-15441	3.50	Circular	0.026	1.31	64	50
P-15442	3.50	Circular	0.014	1.71	53	122
P-15443	3.50	Circular	0.014	1.17	321	101
P-15517	3.50	Circular	0.014	2.11	362	136
P-15518	3.50	Circular	0.014	0.13	600	34
P-15537	7.00	Circular	0.014	0.10	62	184
P-15631	2.50	Circular	0.014	0.28	218	20
P-15724.1	10.67	Special	0.014	0.26	102	519
P-15798	8.00	Circular	0.014	0.10	962	268
P-15926	7.00	Circular	0.014	0.15	254	230
P-15927	7.00	Circular	0.014	0.15	847	231
P-15937	1.50	Circular	0.014	0.51	175	7
P-15944	0.67	Circular	0.009	1.55	136	2
P-15978	8.50	Circular	0.014	0.02	303	128
P-15986	10.67	Special	0.014	0.14	459	390

Name	Diameter (ft)	Shape	Roughness	Conduit Slope (%)	Length (ft)	Design Flow (cfs)
P-16022	8.00	Circular	0.014	0.19	251	374
P-16023	7.50	Circular	0.014	0.42	132	464
P-16026	8.00	Circular	0.014	0.20	195	383
P-16029	8.00	Circular	0.014	0.30	210	464
P-16032	8.00	Circular	0.014	0.13	319	308
P-16035	8.00	Circular	0.014	0.29	205	459
P-16039	8.00	Circular	0.014	0.00	241	27
P-16043	8.00	Circular	0.014	0.02	244	121
P-16048	8.00	Circular	0.014	0.15	1,071	329
P-16054.1	10.67	Special	0.014	0.02	532	148
P-16387.1	4.50	Circular	0.014	0.64	73	146
P-16389.1	4.50	Circular	0.014	0.77	194	161
P-16395	4.50	Circular	0.014	0.62	486	142
P-16396	4.50	Circular	0.014	0.31	73	102
P-16397	4.50	Circular	0.014	1.02	158	184
P-16398	4.50	Circular	0.014	0.41	456	117
P-16399	6.50	Circular	0.014	0.88	39	457
P-16400	6.50	Circular	0.014	0.32	102	276
P-16401	6.50	Circular	0.014	0.40	30	307
P-16402	6.50	Circular	0.014	0.34	207	283
P-16403	6.50	Circular	0.014	0.35	199	289
P-16426	7.00	Circular	0.014	0.34	208	344
P-16427.1	7.00	Circular	0.014	0.31	70	332
P-16430	7.00	Circular	0.014	0.10	149	188
P-16433	7.00	Circular	0.014	0.10	239	188
P-16434	7.00	Circular	0.014	0.10	164	186
P-16471	1.50	Circular	0.014	1.95	141	14
P-16505	7.00	Circular	0.014	0.15	258	231
P-16517	7.00	Circular	0.014	0.10	186	185
P-16637	1.50	Circular	0.009	0.17	46	6
P-16638	1.50	Circular	0.009	0.48	258	10
P-16639	1.50	Circular	0.009	2.07	30	22
P-16692	3.50	Circular	0.014	0.18	528	40
P-16856	8.00	Circular	0.014	0.32	333	478
P-16944	1.50	Circular	0.014	0.59	46	7
P-16964	1.50	Circular	0.014	2.48	347	15
P-16969	4.00	Circular	0.014	0.73	190	114
P-16979	1.50	Circular	0.014	0.54	159	7
P-17545	1.00	Circular	0.014	4.58	7	7
P-17546	1.00	Circular	0.014	5.29	6	8
P-1870	6.50	Circular	0.014	0.00	35	15
P-1871	7.00	Circular	0.014	0.18	103	255
P-2	2.50	Circular	0.014	0.19	31	17
P-200	4.00	Circular	0.014	2.53	83	212
P-2273	3.50	Circular	0.014	0.27	279	48

Name	Diameter (ft)	Shape	Roughness	Conduit Slope (%)	Length (ft)	Design Flow (cfs)
P-2283.1	3.50	Circular	0.014	0.18	22	40
P-2387E	2.50	Circular	0.014	0.91	15	36
P-2387N	6.50	Circular	0.014	30.11	34	2,672
P-2390.1	5.00	Circular	0.014	0.74	317	208
P-23901	5.00	Circular	0.014	0.43	506	159
P-2466	7.00	Circular	0.014	0.19	1,276	257
P-2471	7.00	Circular	0.014	0.87	157	554
P-2477	7.00	Circular	0.014	0.68	388	490
P-2796	7.00	Circular	0.014	0.10	188	184
P-2799	7.00	Circular	0.014	0.10	190	187
P-2804	7.00	Circular	0.014	0.10	179	188
P-2848	8.61	Rectangular	0.014	0.06	68	387
P-2902	7.50	Circular	0.014	0.09	585	211
P-2910	7.50	Circular	0.014	0.43	166	470
P-2913	7.50	Circular	0.014	0.22	303	335
P-2927	7.50	Circular	0.014	0.08	168	198
P-2932	7.50	Circular	0.014	0.22	268	337
P-2941	7.50	Circular	0.014	0.00	255	45
P-2943	7.50	Circular	0.014	-0.01	303	71
P-2956	5.00	Circular	0.014	0.02	1,031	37
P-2990	7.50	Circular	0.014	0.13	151	260
P-300	4.00	Circular	0.014	1.40	20	158
P-3012	7.50	Circular	0.014	0.05	116	163
P-3059	8.50	Circular	0.014	0.22	357	468
P-3097	8.00	Circular	0.014	0.32	284	480
P-3161	8.50	Circular	0.014	0.08	38	279
P-3161001	8.50	Circular	0.014	0.01	276	120
P-3163	8.50	Circular	0.014	0.02	172	152
P-3165	8.50	Circular	0.014	0.02	112	133
P-3168	8.00	Circular	0.014	0.73	102	726
P-3173	8.00	Circular	0.014	0.39	291	532
P-3177	8.00	Circular	0.014	0.40	288	535
P-3178	8.00	Circular	0.014	0.40	241	537
P-3181	8.00	Circular	0.014	0.36	129	505
P-3182.1	8.00	Circular	0.014	0.41	170	543
P-3183.1	8.00	Circular	0.014	0.98	62	838
P-3185.1	8.00	Circular	0.014	0.39	266	527
P-3189.1	8.00	Circular	0.014	0.27	171	439
P-3192	8.00	Circular	0.014	0.36	472	510
P-3194	8.00	Circular	0.014	0.47	126	579
P-3200	8.00	Circular	0.014	0.29	346	458
P-3202	8.00	Circular	0.014	0.36	146	510
P-3206	8.00	Circular	0.014	0.29	172	453
P-3209	8.00	Circular	0.014	0.42	142	546
P-3315	7.00	Circular	0.014	0.10	183	186

Name	Diameter (ft)	Shape	Roughness	Conduit Slope (%)	Length (ft)	Design Flow (cfs)
P-3318	7.00	Circular	0.014	0.11	36	199
P-3320	7.00	Circular	0.014	0.06	199	140
P-3323	7.00	Circular	0.014	0.00	33	19
P-368	6.50	Circular	0.014	0.63	139	385
P-371	6.50	Circular	0.014	0.30	293	267
P-3905	1.00	Circular	0.029	0.77	45	1
P-3960	0.67	Circular	0.009	1.65	108	2
P-3961	0.67	Circular	0.009	2.12	89	3
P-3967	3.50	Circular	0.014	0.04	139	18
P-4	5.00	Circular	0.014	0.09	346	72
P-400	4.00	Circular	0.014	0.71	5	73
P-4081	1.00	Circular	0.014	0.45	274	2
P-4160	6.50	Circular	0.014	0.23	289	231
P-4162	7.00	Circular	0.014	0.59	289	456
P-4180	6.50	Circular	0.014	0.36	272	294
P-4183	6.50	Circular	0.014	0.36	294	291
P-4239	6.50	Circular	0.014	0.35	305	288
P-4466.1	4.00	Circular	0.014	0.66	427	108
P-4467	4.00	Circular	0.014	0.85	225	123
P-4468	3.50	Circular	0.014	2.51	126	148
P-4498	6.50	Circular	0.014	0.35	448	289
P-4536	6.50	Circular	0.014	0.68	40	402
P-4538	6.50	Circular	0.014	0.32	162	276
P-4597	8.00	Circular	0.014	0.39	563	532
P-4655	8.00	Circular	0.014	0.28	350	448
P-4664	8.00	Circular	0.014	0.17	271	345
P-4696	8.00	Circular	0.014	0.38	533	519
P-4818	8.00	Circular	0.014	0.15	686	323
P-4967	4.00	Circular	0.014	0.83	295	122
P-4970	4.50	Circular	0.014	0.81	304	164
P-4979.1	4.50	Circular	0.014	0.64	326	146
P-4992.1	4.50	Circular	0.014	0.80	327	164
P-4996.1	5.00	Circular	0.014	0.46	613	163
P-500	4.00	Circular	0.014	0.69	262	111
P-5010.1	2.50	Circular	0.014	1.20	56	42
P-5026	2.00	Circular	0.014	0.12	394	7
P-5368	5.00	Circular	0.014	0.08	512	67
P-5425	4.00	Circular	0.014	0.60	764	95
P-5430	4.00	Circular	0.014	-0.77	8	117
P-5431	4.00	Circular	0.014	-0.12	312	45
P-5447	3.50	Circular	0.014	24.65	6	464
P-5448	4.00	Circular	0.014	0.21	163	61
P-5451.1	3.50	Circular	0.014	0.77	175	82
P-5454.1	3.50	Circular	0.014	0.73	298	80
P-5458.1	3.50	Circular	0.014	1.16	92	101

Name	Diameter (ft)	Shape	Roughness	Conduit Slope (%)	Length (ft)	Design Flow (cfs)
P-5469	3.50	Circular	0.014	0.45	252	63
P-5473.1	3.50	Circular	0.014	0.31	84	52
P-5489.1	3.50	Circular	0.014	0.31	270	52
P-5491.1	3.50	Circular	0.014	0.30	370	51
P-5548	2.50	Circular	0.014	0.80	351	34
P-5551	2.50	Circular	0.014	0.60	449	30
P-5554.1	2.50	Circular	0.014	0.60	214	30
P-5569.1	2.50	Circular	0.014	0.80	249	34
P-5606	1.50	Circular	0.009	3.33	28	28
P-5607	1.50	Circular	0.014	0.25	303	5
P-5608	1.50	Circular	0.026	5.47	20	11
P-5609	0.83	Circular	0.014	-5.58	5	5
P-5610	0.83	Circular	0.009	2.46	37	5
P-5611	0.67	Circular	0.029	2.12	26	1
P-5612	1.50	Circular	0.014	1.02	305	10
P-5613	0.67	Circular	0.026	2.62	26	1
P-5614	0.83	Circular	0.014	0.38	111	1
P-5615	0.67	Circular	0.029	2.88	14	1
P-5616	1.25	Circular	0.014	0.69	235	5
P-5617	1.25	Circular	0.014	1.90	125	8
P-5618	0.67	Circular	0.029	2.91	39	1
P-5619	1.00	Circular	0.026	2.23	48	2
P-5620	1.00	Circular	0.026	3.13	37	3
P-5621	0.67	Circular	0.026	4.89	34	1
P-5622	1.25	Circular	0.014	3.55	205	11
P-5623	1.25	Circular	0.014	1.85	117	8
P-5624	2.00	Circular	0.014	0.75	339	18
P-5625	1.00	Circular	0.027	2.08	25	2
P-5626	0.83	Circular	0.026	2.90	31	2
P-5627	0.83	Circular	0.027	2.51	42	1
P-5628	1.00	Circular	0.026	55.62	4	12
P-5629	0.67	Circular	0.026	23.29	22	3
P-5630	1.00	Circular	0.026	3.59	47	3
P-5631	0.67	Circular	0.026	5.20	43	1
P-5632	1.00	Circular	0.026	6.07	40	4
P-5633	0.67	Circular	0.026	1.71	29	1
P-5634	4.00	Circular	0.014	0.69	39	111
P-5635	1.00	Circular	0.026	6.89	57	4
P-5636	1.00	Circular	0.014	2.92	263	6
P-5637	1.00	Circular	0.026	6.53	26	4
P-5638	0.83	Circular	0.026	3.43	22	2
P-5639	3.50	Circular	0.014	1.24	48	104
P-5640	0.83	Circular	0.026	-0.67	9	1
P-5641	3.50	Circular	0.014	1.30	254	107
P-5648	1.00	Circular	0.029	0.27	45	1

Name	Diameter (ft)	Shape	Roughness	Conduit Slope (%)	Length (ft)	Design Flow (cfs)
P-5649	1.25	Circular	0.017	0.25	336	2
P-5650	0.83	Circular	0.026	1.05	38	1
P-5651	0.83	Circular	0.026	0.23	35	0
P-5652	0.83	Circular	0.026	2.61	42	2
P-5653	1.25	Circular	0.014	0.80	398	5
P-5654	0.83	Circular	0.029	1.68	62	1
P-5655	0.83	Circular	0.026	3.40	39	2
P-5656	0.83	Circular	0.026	1.51	48	1
P-5657	0.83	Circular	0.026	1.00	18	1
P-5658	1.25	Circular	0.014	0.56	206	4
P-5659	0.83	Circular	0.026	1.45	32	1
P-5660	0.83	Circular	0.026	1.93	31	1
P-5661	1.25	Circular	0.014	0.00	31	0
P-5662	0.83	Circular	0.026	0.86	35	1
P-5663	1.00	Circular	0.026	1.95	30	2
P-5664	1.25	Circular	0.014	1.26	350	7
P-5665	0.83	Circular	0.026	0.90	25	1
P-5666	1.00	Circular	0.026	0.53	30	1
P-5667	1.50	Circular	0.014	0.35	404	6
P-5668	0.83	Circular	0.026	2.09	49	1
P-5669	1.50	Circular	0.014	0.38	440	6
P-5670	0.83	Circular	0.026	1.52	7	1
P-5671	0.83	Circular	0.026	1.44	35	1
P-5672	1.00	Circular	0.026	4.56	42	3
P-5673	0.83	Circular	0.026	0.93	11	1
P-5674	1.50	Circular	0.014	0.18	288	4
P-5675	1.00	Circular	0.026	0.27	49	1
P-5676	0.83	Circular	0.026	0.14	35	0
P-5677	1.50	Circular	0.009	0.91	102	14
P-5678	1.00	Circular	0.026	10.72	5	5
P-5679	0.83	Circular	0.026	22.71	10	5
P-5680	1.50	Circular	0.014	0.26	299	5
P-5681	0.83	Circular	0.026	4.58	39	2
P-5682	0.83	Circular	0.026	1.23	10	1
P-5683	0.83	Circular	0.026	1.50	29	1
P-5684	1.25	Circular	0.014	0.15	296	2
P-5685	1.00	Circular	0.026	0.29	242	1
P-5687	1.25	Circular	0.026	4.44	21	6
P-5688	1.25	Circular	0.026	1.55	39	3
P-5691	2.00	Circular	0.014	0.94	107	20
P-5695	2.00	Circular	0.014	2.17	311	32
P-5697	1.00	Circular	0.026	4.06	46	3
P-5698	2.00	Circular	0.014	2.32	230	32
P-5699	1.00	Circular	0.026	1.81	54	2
P-5700	0.83	Circular	0.026	3.74	49	2

Name	Diameter (ft)	Shape	Roughness	Conduit Slope (%)	Length (ft)	Design Flow (cfs)
P-5701	0.83	Circular	0.026	4.71	21	2
P-5702	1.50	Circular	0.014	0.19	488	4
P-5703	0.83	Circular	0.026	-1.89	16	1
P-5704	0.83	Circular	0.026	1.36	20	1
P-5705S	1.50	Circular	0.014	0.25	400	5
P-5706	0.67	Circular	0.026	2.27	26	1
P-5707	0.83	Circular	0.009	3.21	40	6
P-5708	0.67	Circular	0.017	2.87	45	2
P-5709	0.67	Circular	0.017	1.12	37	1
P-5710	0.67	Circular	0.026	-2.63	8	1
P-5711	1.50	Circular	0.014	3.84	21	19
P-5712	0.67	Circular	0.017	3.51	33	2
P-5713	0.67	Circular	0.020	4.71	37	2
P-5714	0.67	Circular	0.017	1.89	38	1
P-5715	0.83	Circular	0.012	2.61	53	4
P-5716	0.67	Circular	0.017	1.45	43	1
P-5717	2.00	Circular	0.014	0.34	270	12
P-5718	0.67	Circular	0.020	2.72	22	1
P-5719	0.67	Circular	0.017	5.40	16	2
P-5720	0.67	Circular	0.012	0.40	25	1
P-5721	1.25	Circular	0.014	-0.24	124	3
P-5722	0.67	Circular	0.017	4.91	36	2
P-5724	2.00	Circular	0.014	0.69	182	17
P-5725	0.67	Circular	0.017	7.64	26	3
P-5726	0.67	Circular	0.020	4.39	19	2
P-5727	0.67	Circular	0.017	2.29	23	1
P-5728	0.67	Circular	0.017	1.65	41	1
P-5729	2.00	Circular	0.014	0.57	237	16
P-5733	0.67	Circular	0.017	2.78	41	2
P-5734	0.83	Circular	0.009	1.28	42	4
P-5735	1.00	Circular	0.014	4.56	258	7
P-5736	0.67	Circular	0.026	1.00	36	1
P-5737	0.83	Circular	0.009	10.18	17	10
P-5738	1.00	Circular	0.017	0.46	295	2
P-5739	0.67	Circular	0.017	2.82	35	2
P-5740	0.83	Circular	0.009	6.23	48	8
P-5741	0.67	Circular	0.026	1.63	35	1
P-5742	0.67	Circular	0.028	4.27	38	1
P-5743	0.67	Circular	0.026	1.05	16	1
P-5744	1.00	Circular	0.017	1.75	195	4
P-5746	0.67	Circular	0.026	3.20	42	1
P-5747	0.67	Circular	0.017	3.69	70	2
P-5748	0.67	Circular	0.017	3.85	64	2
P-5749	0.67	Circular	0.020	2.68	13	1
P-5750	1.00	Circular	0.014	1.41	127	4

Name	Diameter (ft)	Shape	Roughness	Conduit Slope (%)	Length (ft)	Design Flow (cfs)
P-5751	0.67	Circular	0.017	2.89	21	2
P-5752	1.00	Circular	0.014	1.99	29	5
P-5754	1.00	Circular	0.014	3.26	430	6
P-5755	1.00	Circular	0.014	2.01	25	5
P-5756	1.00	Circular	0.014	2.05	11	5
P-5757	1.75	Circular	0.014	1.25	63	12
P-5758	1.00	Circular	0.014	1.97	20	5
P-5759	1.00	Circular	0.014	1.97	18	5
P-5760	1.00	Circular	0.014	2.03	10	5
P-5761	1.75	Circular	0.014	0.68	79	12
P-5762	1.00	Circular	0.014	2.00	34	5
P-5763	1.00	Circular	0.014	2.00	25	5
P-5764	1.00	Circular	0.014	2.09	36	5
P-5765	4.00	Circular	0.014	0.87	312	125
P-5766	0.67	Circular	0.017	2.38	61	1
P-5767	0.67	Circular	0.017	7.31	15	3
P-5768	0.83	Circular	0.017	0.73	99	1
P-5769	0.67	Circular	0.017	3.84	28	2
P-5770	4.00	Circular	0.014	0.82	375	121
P-5771	0.67	Circular	0.026	4.22	20	1
P-5772	0.67	Circular	0.017	1.41	72	1
P-5773	1.00	Circular	0.014	6.41	88	8
P-5774	1.00	Circular	0.014	5.57	32	8
P-5775	0.83	Circular	0.026	7.48	10	3
P-5776	1.00	Circular	0.014	3.42	50	6
P-5777	0.83	Circular	0.026	5.34	18	2
P-5778	0.83	Circular	0.026	3.35	22	2
P-5779	0.83	Circular	0.026	3.53	7	2
P-5780	1.00	Circular	0.014	2.69	317	5
P-5781	0.67	Circular	0.026	6.63	28	1
P-5782	1.25	Circular	0.014	8.56	99	18
P-5784	0.67	Circular	0.017	1.35	45	1
P-5785	0.34	Circular	0.017	6.99	20	0
P-5786	0.67	Circular	0.017	2.24	25	1
P-5787	0.83	Circular	0.009	2.57	13	5
P-5788	1.25	Circular	0.016	0.31	389	3
P-5789	1.00	Circular	0.017	28.87	14	15
P-5790	0.67	Circular	0.017	4.65	30	2
P-5791	4.00	Circular	0.014	2.53	10	212
P-5792	1.00	Circular	0.009	1.50	43	6
P-5793	1.00	Circular	0.014	2.18	14	5
P-5794	1.50	Circular	0.014	0.84	181	9
P-5795	1.00	Circular	0.014	0.41	22	2
P-5796	0.67	Circular	0.017	7.46	50	3
P-5797	0.67	Circular	0.009	3.47	22	3

Name	Diameter (ft)	Shape	Roughness	Conduit Slope (%)	Length (ft)	Design Flow (cfs)
P-5798	1.00	Circular	0.014	1.56	232	4
P-5799	0.67	Circular	0.009	2.42	16	3
P-5800	4.00	Circular	0.014	0.73	256	144
P-5801	0.67	Circular	0.028	3.25	9	1
P-5802	0.67	Circular	0.026	2.61	30	1
P-5803	0.67	Circular	0.026	2.82	35	1
P-5804	4.00	Circular	0.014	0.89	328	126
P-5805	0.67	Circular	0.026	5.72	24	1
P-5806	0.67	Circular	0.026	4.71	59	1
P-5816	0.50	Circular	0.017	0.67	16	0
P-5817	0.50	Circular	0.017	0.40	30	0
P-5818	1.00	Circular	0.014	1.40	285	4
P-5819	0.83	Circular	0.026	0.51	41	1
P-5820	0.50	Circular	0.017	0.48	50	0
P-600	4.00	Circular	0.014	0.96	221	130
P-6023	0.67	Circular	0.009	2.96	45	3
P-6024	0.83	Circular	0.009	1.18	32	3
P-6025	0.67	Circular	0.017	7.72	15	3
P-6026	2.50	Circular	0.014	0.63	329	30
P-6028	2.50	Circular	0.014	0.61	316	30
P-6032	2.50	Circular	0.014	2.38	304	59
P-6040	2.50	Circular	0.014	0.51	445	27
P-6046	2.50	Circular	0.014	0.79	225	34
P-6049	2.50	Circular	0.014	2.65	255	62
P-6054	2.50	Circular	0.014	1.38	163	45
P-6057	3.50	Circular	0.014	0.19	260	41
P-6072	3.50	Circular	0.014	0.19	270	40
P-6084	3.50	Circular	0.014	0.27	171	48
P-6087	3.50	Circular	0.014	0.18	221	40
P-6089	3.50	Circular	0.014	0.25	189	47
P-6125	7.00	Circular	0.014	0.34	279	344
P-6128	7.00	Circular	0.014	0.25	107	298
P-6132	3.50	Circular	0.014	0.50	232	66
P-6134	3.50	Circular	0.014	0.40	296	59
P-6136	3.50	Circular	0.014	0.44	187	62
P-6137	3.50	Circular	0.014	0.54	280	69
P-6139	3.50	Circular	0.014	0.38	272	57
P-6213	7.50	Circular	0.014	0.32	490	401
P-6220	7.50	Circular	0.014	0.12	181	243
P-7 ¹	0.00	Natural	0.014	0.45	114	151,685
P-700	3.00	Circular	0.014	1.00	18	62
P-705E.1	1.50	Circular	0.014	0.81	288	9
P-7384	6.00	Circular	0.014	0.21	203	181
P-7388	6.00	Circular	0.014	0.24	287	192
P-7391	6.00	Circular	0.014	0.25	183	195

Name	Diameter (ft)	Shape	Roughness	Conduit Slope (%)	Length (ft)	Design Flow (cfs)
P-7397	6.00	Circular	0.014	0.61	202	307
P-7481	4.00	Circular	0.014	-2.62	75	216
P-7497	3.50	Circular	0.014	0.15	39	37
P-7566.1	2.50	Circular	0.014	0.83	249	35
P-7571	2.50	Circular	0.014	2.62	308	62
P-7637	2.50	Circular	0.014	0.05	186	9
P-7640	2.50	Circular	0.014	0.29	95	21
P-7641	2.50	Circular	0.014	1.83	65	52
P-7642	2.50	Circular	0.014	0.79	202	34
P-7725	6.50	Circular	0.014	0.67	45	397
P-7728	6.50	Circular	0.014	0.24	220	239
P-7731	6.50	Circular	0.014	0.19	245	211
P-800	10.67	Special	0.014	0.02	312	143
P-8028	6.50	Circular	0.014	0.36	70	291
P-8029E	6.50	Circular	0.014	0.20	10	218
P-8029N	4.00	Circular	0.014	4.68	31	288
P-8035	6.50	Circular	0.014	0.27	243	252
P-8036	6.50	Circular	0.014	0.35	173	287
P-8039.1	6.50	Circular	0.014	0.41	171	310
P-8042.1	6.50	Circular	0.014	0.75	154	423
P-8051	1.00	Circular	0.014	1.98	8	5
P-8053	4.00	Circular	0.014	0.46	291	91
P-8054	4.00	Circular	0.014	0.69	16	111
P-8055	1.75	Circular	0.014	0.67	102	12
P-8064	4.00	Circular	0.014	0.60	185	103
P-8070	4.00	Circular	0.014	0.72	214	113
P-8094	4.00	Circular	0.014	0.58	99	102
P-8145	2.50	Circular	0.014	1.27	246	43
P-8161.1	3.00	Circular	0.014	0.40	396	39
P-8162	3.50	Circular	0.014	0.98	106	93
P-8163.1	2.50	Circular	0.014	1.05	119	39
P-8165	3.00	Circular	0.014	0.49	226	43
P-8256	6.50	Circular	0.014	0.31	39	269
P-8258.1	6.50	Circular	0.014	0.31	235	269
P-8261.1	6.50	Circular	0.014	0.35	256	287
P-8346.1	4.50	Circular	0.014	0.59	88	141
P-8347	1.50	Circular	0.014	1.50	148	12
P-8353.1	4.50	Circular	0.014	0.71	428	154
P-8378.1	4.50	Circular	0.014	0.66	307	148
P-8381.1	4.50	Circular	0.014	0.23	419	87
P-8384.1	4.00	Circular	0.014	1.39	151	158
P-8387.1	4.00	Circular	0.014	0.84	142	122
P-8402	4.00	Circular	0.014	1.14	291	142
P-8404	4.00	Circular	0.014	1.12	267	141
P-8410	4.00	Circular	0.014	1.36	314	156

Name	Diameter (ft)	Shape	Roughness	Conduit Slope (%)	Length (ft)	Design Flow (cfs)
P-8412	4.00	Circular	0.014	1.26	97	150
P-8551	3.50	Circular	0.014	0.96	310	92
P-900.1	10.67	Special	0.014	0.24	228	500
P-9447	7.00	Circular	0.014	0.15	113	230
P-9468	3.50	Circular	0.014	0.18	193	40
P-9488	3.50	Circular	0.014	0.19	161	40
P-9489	4.00	Circular	0.014	1.39	300	157
P-9727	2.50	Circular	0.014	0.32	294	21
P-9728	1.25	Circular	0.014	0.56	208	4
P-9731	2.00	Circular	0.014	0.84	314	19
P-9732	2.50	Circular	0.014	0.39	312	24
P-9733	0.83	Circular	0.026	-1.18	4	1
P-9735	4.00	Circular	0.014	0.77	298	117
P-9736	1.00	Circular	0.017	4.29	305	6
P-9738	4.00	Circular	0.014	0.50	153	95
P-9745	4.00	Circular	0.014	1.82	219	180
P-9763	6.00	Circular	0.014	0.12	219	138
P-9764	6.00	Circular	0.014	0.32	158	221
P-9765	6.00	Circular	0.014	0.11	306	131
P-9766	6.00	Circular	0.014	0.19	189	169
P-9823	8.00	Circular	0.014	0.23	142	403
P-9886	6.50	Circular	0.014	0.17	218	200
P-9891	6.50	Circular	0.014	0.45	214	328
P-9996.1	4.00	Circular	0.014	0.96	303	131
P-GRAY	1.25	Circular	0.014	3.50	8	11
PC_W1	0.05	Circular	0.014	0.00	10	0
PC_W1	0.05	Circular	0.014	0.00	10	0
PC_W2	0.05	Circular	0.014	0.00	10	0
PC_W2	0.05	Circular	0.014	0.00	10	0
PC_W3	0.05	Circular	0.014	0.00	10	0
PC_W3	0.05	Circular	0.014	0.00	10	0
PCTANK_O1	0.05	Circular	0.014	0.00	10	1,816
PCTANK_O1	0.05	Circular	0.014	0.00	10	1,816
S-10	1.00	Natural	0.014	1.15	88	190
S-10001	0.00	Natural	0.014	1.26	353	198
S-10199	1.00	Natural	0.014	0.13	179	63
S-10231	1.00	Natural	0.014	0.48	86	219
S-10232	1.00	Natural	0.014	0.00	258	230
S-10233	1.00	Natural	0.014	-0.45	42	118
S-10299	1.00	Natural	0.014	0.06	289	43
S-10300	0.00	Natural	0.014	0.72	280	269
S-10361	0.00	Natural	0.015	-0.95	420	173
S-10362	1.00	Natural	0.014	0.13	428	63
S-10464	1.00	Natural	0.014	0.00	333	97
S-10549	1.00	Natural	0.014	0.00	56	6

Name	Diameter (ft)	Shape	Roughness	Conduit Slope (%)	Length (ft)	Design Flow (cfs)
S-10862	1.00	Natural	0.014	1.07	259	183
S-11073	1.00	Natural	0.014	0.00	61	6
S-11074	1.00	Natural	0.014	1.19	221	193
S-11081	0.00	Natural	0.015	1.86	289	241
S-11272	0.00	Natural	0.014	0.29	134	95
S-11414	1.00	Natural	0.014	1.21	331	195
S-11484	1.00	Natural	0.014	0.00	169	6
S-11763	1.00	Natural	0.014	1.91	309	439
S-11959	1.00	Natural	0.014	2.12	255	462
S-12547	0.05	Natural	0.014	1.75	66	234
S-12552	1.00	Natural	0.014	0.25	208	158
S-12601	1.00	Natural	0.014	0.19	170	78
S-12737	1.00	Natural	0.014	0.60	275	247
S-12745	1.00	Natural	0.014	0.12	277	111
S-14412	1.00	Natural	0.014	0.40	326	112
S-15306	1.00	Natural	0.014	1.02	174	178
S-15312	1.00	Natural	0.014	1.59	102	223
S-15724	1.00	Natural	0.014	1.81	102	238
S-16054	1.00	Natural	0.014	0.00	532	138
S-16387	1.00	Natural	0.014	0.01	73	17
S-16389	1.00	Natural	0.014	1.03	194	180
S-16427	1.00	Natural	0.014	0.00	70	6
S-2390	0.00	Natural	0.014	1.36	317	207
S-23901	1.00	Natural	0.014	0.57	506	134
S-3182	1.00	Natural	0.014	0.00	170	10
S-3183	1.00	Natural	0.014	0.00	62	10
S-3185	1.00	Natural	0.014	0.75	266	275
S-3189	1.00	Natural	0.014	0.00	171	10
S-4466	1.00	Natural	0.014	0.47	427	121
S-4979	1.00	Natural	0.014	1.69	326	230
S-4992	0.00	Natural	0.014	0.65	327	143
S-4996	1.00	Natural	0.014	0.81	613	159
S-5010	1.00	Natural	0.014	-2.54	56	282
S-5451	1.00	Natural	0.014	0.85	175	163
S-5454	1.00	Natural	0.014	1.64	298	226
S-5458	1.00	Natural	0.014	-0.96	92	173
S-5473	1.00	Natural	0.014	2.39	84	274
S-5489	1.00	Natural	0.014	0.00	270	6
S-5491	1.00	Natural	0.014	0.00	370	6
S-5554	1.00	Natural	0.014	1.69	214	230
S-5569	1.00	Natural	0.014	1.22	249	196
S-7566	1.00	Natural	0.014	0.60	249	137
S-8039	1.00	Natural	0.014	1.17	171	192
S-8042	1.00	Natural	0.014	1.09	154	184
S-8145	0.00	Natural	0.014	1.12	246	187

Name	Diameter (ft)	Shape	Roughness	Conduit Slope (%)	Length (ft)	Design Flow (cfs)
S-8161	1.00	Natural	0.014	0.00	396	99
S-8163	0.00	Natural	0.015	2.73	119	292
S-8258	1.00	Natural	0.014	-0.25	235	88
S-8261	1.00	Natural	0.014	0.09	256	54
S-8346	1.00	Natural	0.014	0.00	88	6
S-8353	1.00	Natural	0.014	0.00	428	148
S-8378	1.00	Natural	0.014	0.00	307	175
S-8381	1.00	Natural	0.014	0.00	419	193
S-8384	1.00	Natural	0.014	0.00	151	250
S-8387	1.00	Natural	0.014	0.00	142	210
S-900	0.00	Natural	0.015	0.95	228	309
S-9996	1.00	Natural	0.014	0.52	303	128

¹ P-1400 and P-7 are open channel sections downstream of the Pike Creek Outfall. These sections were surveyed by the City from the flow line and up approximately 19 feet in elevation. The design flow reported for the XSECTION entered in xp-swmm is thus reported with basically unlimited capacity. In reality, this XSECTION will likely only realize a fraction of the reported design flow.